

Investitor :

**UPRAVA ZA KATASTAR I DRŽAVNU IMOVINU
Bulevar vojvode Stanka Radonjića br.1
"Nova Varoš – Kvarta A", Podgorica**

Objekat:

**ADAPTACIJA MULTIFUNKCIONALNOG
ADMINISTRATIVNOG OBJEKTA ZA POTREBE
ORGANA DRŽAVNE UPRAVE**

Lokacija:

**UP , Koju čine k.p. 2212, 2215/1, 2216 KO Podgorica
II, DUP "Nova Varoš 2", Podgorica**

Vrsta tehničke dokumentacije:

PROJEKAT ADAPTACIJE

Dio tehničke dokumentacije:

**Automatske stabilne instalacije za gašenje požara
vodom – SPRINKLER INSTALACIJE**

Glavni inženjer:

Marko Bešović, spec.sci.arh.

Odgovorni inženjer:

Goran Korać, dipl.maš.inž.

Podgorica, Jan. 2024.god.

SADRŽAJ TERMOTEHNIČKOG PROJEKTA

A	OPŠTE STRANE
A.1	Naslovna strana
A.2.	Sadržaj projekta
B.	TEKSTUALNA DOKUMENTACIJA
B.1.	Tehnički opis
C.	NUMERIČKA DOKUMENTACIJA
C.1	Proračune
C.2	Odabir pumpno postrojenje
C.3	Predmjer i predračun radova
D.	GRAFIČKA DOKUMENTACIJA
	Naziv crteža
	Oznaka crteža
D.1	Osnova nivo -2 sa cijevnim razvodom i rasporedom opreme mlaznice
D.2	Osnova nivo -1 sa cijevnim razvodom i rasporedom opreme mlaznice
D.3	Osnova prizemlja sa cijevnim razvodom i rasporedom opreme mlaznice
D.4	Osnova 1.sprata sa cijevnim razvodom i rasporedom opreme mlaznice
D.5	Osnova 2.sprata sa cijevnim razvodom i rasporedom opreme mlaznice
D.6	Osnova 3.sprata sa cijevnim razvodom i rasporedom opreme mlaznice
D.7	Osnova 4.sprata sa cijevnim razvodom i rasporedom opreme mlaznice
D.8	Osnova 5.sprata sa cijevnim razvodom i rasporedom opreme mlaznice
D.9	Osnova 6.sprata sa cijevnim razvodom i rasporedom opreme mlaznice
D.10	Tehnološka šema
D.11	Detalj ugradnje mlaznica

TEKSTUALNA DOKUMENTACIJA

1.1 TEHNIČKI OPIS SPRINKLER INSTALACIJE

1. LOKACIJA INSTALACIJE

Stabilna automatska instalacija za gašenje požara vodom – sprinkler instalacija predviđena je za gašenje požara u multifunkcionalnom administrativnom objektu u Podgorici. Objekat se sastoji od 9 etaža, Po (-2)+Po(-1)+P+6. Garaža (Podrum -2) je OH2 stepen opasnosti, svi ostali dijelovi se tretiraju kao OH1. Sve viseće mlaznice se montiraju sa fleksibilnim crijevima. Vertikale kroz objekat se vode građevinskim tehničkim vertikalama i svaki sprat ima po dvije vertikale cijelom visinom objekta sa kojih se vrši odvajanje spratne horizontalne sprinkler mreže.

2. OPIS INSTALACIJE

Sprinkler instalacija spada među najefikasnije instalacije za gašenje požara. To je automatska stabilna instalacija za gašenje požara rasprskavajućim mlazom vode, koja u pripremnom položaju prije aktiviranja ima zatvorene mlaznice, koje se otvaraju na određenoj povišenoj temperaturi i na taj način započinje automatsko aktiviranje instalacije. Cjevovodi koji dovode vodu do mlaznica su pod stalnim pritiskom vode. Gašenje požara se vrši određenim brojem mlaznica, zavisno od brzine širenja požara. Pored gašenja, pri aktiviranju sprinkler instalacije istovremeno vrši i dojavu požara davanjem alarmnog signala.

3. TIP INSTALACIJE

Usvojena je mokra sprinkler instalacija, jer u objektu koji se štiti ne postoji mogućnost zamrzavanja vode u cjevovodima. Prostorija za smeštaj opreme obezbijedena je od niskih temperatura. Cjevovodi mokre sprinkler instalacije su stalno napunjeni vodom pod pritiskom. Od trenutka aktiviranja instalacije, trenutno dolazi voda do mjesta gdje se pojavi požar.

4. OSNOVNI ELEMENTI INSTALACIJE

Sprinkler instalacija se sastoji od sledećih elemenata:

- pumpno postrojenje za povišenje pritiska u instalaciji (1 radna elektro pumpa + 1 rezervna elektro pumpa + džokej pumpa za održavanje pritiska u instalaciji u režimu bez požara),
- mokri sprinkler ventil,
- cijevna mreža na kojoj su postavljene sprinkler mlaznice,
- sprinkler mlaznica – viseće i stojeće,
- dovodni cjevovod,
- ostala prateća armatura.

5. SPRINKLER PODSTANICA

Sprinkler podstanica se nalazi u sklopu objekta, na nivou garaže. Temperatura u sprinkler stanici mora biti iznad +5°C.

Za povišenje pritiska u cjevovodnoj mreži sprinkler sistema predviđeno je monokompaktno pumpno postrojenje koje se sastoji od 1 elektro pumpe (radne), 1 elektro pumpe (rezervne) i jedne džokej pumpe, za održavanje pritiska u cjevovodnoj mreži. Ova prostorija je obezbijedena od niskih temperatura.

Rad pumpi:

- džokej pumpa (pumpa za održavanje pritiska u cjevovodnoj mreži) se posredstvom automatike sa presostatima uključuje kada pritisak u instalaciji dostigne određenu vrijednost, a isključuje se kada poveća pritisak u instalaciji na određenu vrijednost;
- elektro pumpa (radna) se posredstvom automatike sa presostatima uključuje kada pritisak u instalaciji dostigne određenu vrijednost. Onog trenutka kada startuje ova pumpa mora se automatski ugasiti džokej pumpa. Rad elektro pumpe znači da imamo stanje požara pa automatsko isključivanje rada ove pumpe ne smije postojati, tj. rad ove pumpe se može samo ručno prekinuti. Takođe ne smije postojati ni zaštita pumpe od rada "na suvo";
- elektro pumpa (rezervna) se posredstvom automatike sa presostatima uključuje ako radna pumpa iz bilo kog razloga nije uspjela da startuje. U trenutku kada pritisak u instalaciji dostigne određenu vrijednost. Rad elektro pumpe znači da imamo stanje požara pa automatsko isključivanje rada ove pumpe ne smije postojati, tj. rad ove pumpe može biti samo ručno prekinut. Takođe ne smije postojati ni zaštita pumpe od rada "na suvo".

Signalni pumpi:

Svi signalni, dobijeni od monokompaktnog pumpnog postrojenja, moraju biti dati u okviru sistema za nadzor i upravljanje.

- džokej pumpa
 - rad džokej pumpe
 - kvar džokej pumpe
- elektro pumpa (radna)
 - spremna za rad
 - neuspjeli start
 - rad elektro pumpe
- elektro pumpa (rezervna)
 - spremna za rad
 - neuspjeli start
 - rad elektro pumpe

Signalni od ovalnih zasuna:

Mikroprekidači na ovim ovalnim zasunima treba da daju, u okviru sistema za nadzor i upravljanje ili sistema za dojavu požara, signal ako ventil nije u odgovarajućem položaju.

Signal presostata mokrog sprinkler ventila:

Presostat sprinkler ventila daje signal da je podignuta klapna mokrog sprinkler ventila. Ovakav signal znači moguć požar jer klapna sprinkler ventila može biti malo otvorena usled zaglavljivanja klapne sprinkler ventila. Zbog mogućnosti da se desi takva situacija, ovaj signal se šalje protivpožarnom sistemu. Ovaj signal treba da indukuje interni alarm u prostoriji sistema za nadzor i upravljanje. Akcije koje moraju uslijediti moraju biti adekvatne za stanju požara, ali bez izvršnih funkcija protivpožarne centrale (primjer: obaranje protivpožarnih klapni).

Signalni indikatora protoka:

Indikator protoka je uređaj koji usled kretanja vode kroz cijev (u jednom smjeru) daje kontakt koji se prenosi ka protivpožarnoj centrali i prema automatskim ventilima sa elektro pogonom. Ovakav signal se tretira kao siguran požar. Izvršne funkcije protivpožarne centrale moraju biti adekvatne stanju požara. Indikator protoka se nalazi na horizontalnom dijelu cjevovoda, i to na dovodnom cevovodu iz sprinkler pumpne stanice. Za ovaj sistem predviđeno je 14 indikatora protoka, nadzemne etaže i Podrum (-1) po dva indikatora i Podrum (-2) jedan indikator protoka.

Priklučak za vatrogasno vozilo:

je priključak koji se nalazi na prizemnom nivou objekta, na oko 1.0 m iznad nivoa terena, i on je još jedna mjera sigurnosti, koja omogućava da se vatrogasno vozilo priključi na sprinkler sistem i da na taj način gasi požar. Ova dodatna mjera sigurnosti je predviđena u slučaju da u sistemu nema dovoljno vode.

Alarmna mokra sprinkler stanica:

sadrži nepovratnu klapnu koja je u zatvorenom položaju usled jednakih pritisaka uzvodno i nizvodno od klapne. Ovo uravnovešenje pritisaka se obavlja preko bajpasnom klapnom. U slučaju požara, ampula sprinkler mlaznice puca. Pritisak iznad klapne (nizvodno) pada, omogućujući klapni da se otvori i propusti potrebnu količinu vode do sprinkler mlaznica. Detaljnije objašnjenje je dano tačkom 8. Način rada instalacije.

6. MREŽA CJEVOVODA

Mreža cjevovoda ima osnovnu funkciju da spaja sprinkler mlaznice sa izvorom vode, osiguravajući osnovne potrebne parametre – količinu vode i pritisak. Vodi se tako da se pokrije cijela površina koja se štiti. Izrađuje se od crnih bešavnih cjevi.

Cjevi se međusobno spajaju mehaničkim spojnicama iznad prečnika DN50 a za DN50 i manje prečnike, spajanje je predviđeno pocinkovanim navojnim fittingom prema preporukama CEA 4001.

Cjevovodi se vode sa nagibom prema mjestima ispusta, kako bi se mogli isprazniti. Na krajevima magistralnih cjevovoda predviđene su slavine za ispiranje DN50.

Pad iznosi:

- 0,4% za glavne cjevi
- 0,2% za razvodne cjevovode

Način formiranja cjevne mreže ima direktni uticaj na uniformnost pokrivanja štićenog prostora. Praktični uslovi i mogućnosti odredili su raspored cjevne mreže i to u zavisnosti od konstrukcije i namjene objekta. Maksimalni dozvoljeni pritisak u cjevovodu ne sme da pređe vrednost od $p_{max.} = 12$ bar.

7. SPRINKLER MLAZNICE

Sprinkler mlaznice su važan elemenat sprinkler instalacije, jer vrše njeno aktiviranje. One se pri određenoj temperaturi otvaraju, a svojom konstrukcijom omogućavaju rasipanje vode tako da ona ravnomjerno kiasi površinu na kojoj se desio požar.

Sprinkler mlaznica se sastoji od sledećih delova:

- tijela mlaznice
- zatvarača kojeg na sjedištu drži ampula ispunjena ekspanzivnom tečnošću
(ampula puca kada temperatura oko mlaznice dostigne vrednost od 68 °C)
- raspršivača učvršćenog na vrhu tijela mlaznice

Sprinkler mlaznice se postavljaju sa deflektorom mlaza okrenutim dole (viseća) u spuštenom plafonu i stojeće (garaža).

Minimalno dozvoljeni pritisak na sprinkler mlaznici iznosi $p_{min} = 0.35$ bar.

8. NAČIN RADA INSTALACIJE

Cjevna mreža je postavljena tako tako da su mlaznice okrenute dole (viseća) i gore (stojeća).

Cijela instalacija je napunjena vodom pod pritiskom.

Svaka mlaznica na svom izlaznom dijelu ima ampulu koja zatvara otvor.

Prilikom pojave temperature od 68°C, dolazi do pucanja ampule na mlaznici usled širenja ekspanzije tečnosti koja se nalazi u ampuli. Na taj način se otvara izlaz vodi.

Voda udara u deflektor i raspršava se tako da u kružnoj lepezi pokriva površinu koja se štiti.

U slučaju da prvo aktivirana sprinkler mlaznica ne uspije da ugasi požar, pa se on proširi, otvaraju se sledeće sprinkler mlaznice u neposrednoj blizini mesta požara.

Usled otvaranja mlaznice pada pritisak u gornjoj komori sprinkler ventila, podiže se klapna u sprinkler ventilu. Voda iz podstanice protiče ka sprinklerskim mlaznicama. Preko žlijeba u sjedištu sprinkler ventila voda ulazi u cjevovod prema hidrauličkom alarmnom zvonu.

Alarmno zvono se nalazi van pumpne stанице, na visini od oko 2 metra od kote poda.

Prilikom kretanja vode u cjevovodima, indikator protoka, daje impuls koji se prenosi na centralu za dojavu požara, a ona zatim daje alarmni signal da je instalacija proradila.

9. SNABDIJEVANJE VODOM SPRINKLER INSTALACIJE

Za pravilan i siguran rad sprinkler instalacije najvažniju ulogu ima sigurno snabdijevanje vodom, dovoljne količine sa potrebnim pritiskom tokom vremena gašenja. Snabdijevanje vodom mora biti pouzdano i ne smije biti ugroženo niskim temperaturama.


Kao neiscrpni izvor vode za sprinkler instalaciju koristiti rezervoar sa redukovani kapacitet pri tome prikljuciti ga na vodovodnom mrežon sa mogućnost dopuna preko ventilima sa plovkom, kapacitet rezervara je 20m³, i ovo je deo projekta vodovod i kanalizacija, i prikazan je na osnova »situacija« objekta

10. SNABDIJEVANJE PUMPI ELEKTRIČNOM ENERGIJOM

Pumpe sprinkler instalacije treba da se napajaju električnom energijom iz dva izvora, gradske distributivne mreže i dizel agregata.


Kablovi koji napajaju električnom energijom pumpe su cijelom dužinom zaštićeni od požara u trajanju od 90 minuta. Način vođenja, način zaštite kao i karakteristike kablova su dati u projektu elektroenergetskih instalacija.

Napomena: Prostor arhive na etaži Podrum (-1) nije obuhvaćen ovom instalacijom jer će taj prostor biti pokriven sistemom za gašenje požara gasom – INERGEN – om.

ŠEMATSKI PRIKAZ RADA MOKROG SPRINKLER VENTILA**SISTEM U NORMALNOM STANJU**


- 1 - Glavni zaporni ventil
- 2 - Klapna sprinkler ventila
- 3 - Ventil za testiranje alarmnog zvona (normalno zatvoren)
- 4 - Glavni drenažni ventil
- 5 - Ventil hidrauličkog alarmnog zvona (normalno otvoren)
- 6 - Odvajač nečistoća
- 7 - Set ograničenog protoka
- 8 - Posuda za eliminisanje lažnog alarma
- 9 - Presostat
- 10 - Hidrauličko alarmno zvono
- 11 - Sprinkler mlaznice

**POČETAK RADA INSTALACIJE
(PUCANJE AMPULE SPRINKLER MLAZNICE)**




- 1 - Glavni zaporni ventil
- 2 - Klapna sprinkler ventila
- 3 - Ventil za testiranje alarmnog zvona (normalno zatvoren)
- 4 - Glavni drenažni ventil
- 5 - Ventil hidrauličkog alarmnog zvona (normalno otvoren)
- 6 - Odvajač nečistoća
- 7 - Set ograničenog protoka
- 8 - Posuda za eliminisanje lažnog alarma
- 9 - Presostat
- 10 - Hidrauličko alarmno zvono
- 11 - Sprinkler mlaznice (PUCANJE AMPULE SPRINKLER MLAZNICE)

PODIZANJE KLAPNE SPRINKLER VENTILA




- 1 - Glavni zaporni ventil
- 2 - Klapna sprinkler ventila
- 3 - Ventil za testiranje alarmnog zvona (normalno zatvoren)
- 4 - Glavni drenažni ventil
- 5 - Ventil hidrauličkog alarmnog zvona (normalno otvoren)
- 6 - Odvajač nečistoća
- 7 - Set ograničenog protoka
- 8 - Posuda za eliminisanje lažnog alarma
- 9 - Presostat
- 10 - Hidrauličko alarmno zvono
- 11 - Sprinkler mlaznice

**PUNJENJE POSUDE ZA ELIMINISANJE LAŽNOG ALARMA
(KADA PROTOK KROZ SET OGRANIČENOG PROTKA POSTANE VEĆI,
POČINJE PUNJENJE POSUDE ZA ELIMINISANJE LAŽNOG ALARMA)**



- 1 - Glavni zaporni ventil
- 2 - Klapna sprinkler ventila
- 3 - Ventil za testiranje alarmnog zvona (normalno zatvoren)
- 4 - Glavni drenažni ventil
- 5 - Ventil hidrauličkog alarmnog zvona
- 6 - Odvajač nečistoća
- 7 - Set ograničenog protoka
- 8 - Posuda za eliminisanje lažnog alarma
- 9 - Presostat
- 10 - Hidrauličko alarmno zvono
- 11 - Sprinkler mlaznice

POČETAK RADA PRESOSTATA I HIDRAULIČKOG ALARMNOG ZVONA



- 1 - Glavni zaporni ventil
- 2 - Klapna sprinkler ventila
- 3 - Ventil za testiranje alarmnog zvona (normalno zatvoren)
- 4 - Glavni drenažni ventil
- 5 - Ventil hidrauličkog alarmnog zvona
- 6 - Odvajač nečistoća
- 7 - Set ograničenog protoka
- 8 - Posuda za eliminisanje lažnog alarm-a
- 9 - Presostat
- 10 - Hidrauličko alarmno zvono
- 11 - Sprinkler mlažnice

NUMERIČKA DOKUMENTACIJA

PRORAČUN – GARAŽA

Fire - Fire Sprinkler Hydraulics Calculation Program pRejKEr Hell		Elite Software Development, Inc. CANU-GARAZA Page 2	
General Project Data Report			
General Data			
Project Title:	CANU-GARAZA	Project File Name:	CANU GARAZA..fiw
Designed By:		Date:	1/3/2024
Code Reference:		Approving Agency:	
Client Name:		Phone:	
Address:		City, State Zip Code:	
Company Name:		Representative:	
Company Address:		City And State:	
Phone:		Building Owner:	
Building Name:		Phone at Building:	
Contact at Building:		City, State Zip Code:	
Address Of Building:			
Project Data			
Description Of Hazard:	OH2	Sprinkler System Type:	Wet
Design Area Of Water Application:	144 m ²	Maximum Area Per Sprinkler:	12 m ²
Default Sprinkler K-Factor:	80.00 Km	Default Pipe Material:	SCHED 40 WET STEEL
Inside Hose Stream Allowance:	0.00 Lpm	Outside Hose Stream Allowance:	0.00 Lpm
In Rack Sprinkler Allowance:	0.00 Lpm		
Sprinkler Specifications			
Make:	VIKING	Model:	MX5
Size:	DN15	Temperature Rating:	67.79 C
Water Supply Test Data			
Source Of Information:			
Test Hydrant ID:		Date Of Test:	
Hydrant Elevation:	0 m	Static Pressure:	0.00 kPa
Test Flow Rate:	0.00 Lpm	Test Residual Pressure:	0.00 kPa
Calculated System Flow Rate:	1112.51 Lpm	Calculated Inflow Residual Pressure:	210.66 kPa
Calculation Project Data			
Calculation Mode:	Demand		
HMD Minimum Residual Pressure:	56.00 kPa	Minimum Desired Flow Density:	5.00 Lpm/m ²
Number Of Active Nodes:	40		
Number Of Active Pipes:	39	Number Of Inactive Pipes:	0
Number Of Active Sprinklers:	16	Number Of Inactive Sprinklers:	0

Fire - Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell				Elite Software Development, Inc. CANU-GARAZA Page 3					
Fire Sprinkler Input Data									
Node Input Data									
Node No.	Node Description Branch Description	Area Group Branch Dia. (cm)	Sprinkler KFactor (Km) Branch Len. (m)	Pressure Estimate (kPa) Branch Stnd Fittings	Node Elev (m) Branch Non- Snd Fittings (m)	Non-Sprinkler Flow (Lpm) Branch Sprk KFactor (Km)			
1	Sprinkler ---	---	80.00 0.0	56.29 ---	2.50 0.0	0.00 0.00			
2	Sprinkler ---	---	80.00 0.0	61.65 ---	2.50 0.0	0.00 0.00			
3	Sprinkler ---	---	80.00 0.0	81.20 ---	2.50 0.0	0.00 0.00			
4	Sprinkler ---	---	80.00 0.0	61.65 ---	2.50 0.0	0.00 0.00			
5	Sprinkler ---	---	80.00 0.0	67.50 ---	2.50 0.0	0.00 0.00			
6	Sprinkler ---	---	80.00 0.0	88.49 ---	2.50 0.0	0.00 0.00			
7	Sprinkler ---	---	80.00 0.0	65.52 ---	2.50 0.0	0.00 0.00			
8	Sprinkler ---	---	80.00 0.0	68.74 ---	2.50 0.0	0.00 0.00			
9	Sprinkler ---	---	80.00 0.0	87.70 ---	2.50 0.0	0.00 0.00			
10	Sprinkler ---	---	80.00 0.0	69.22 ---	2.50 0.0	0.00 0.00			
11	Sprinkler ---	---	80.00 0.0	72.61 ---	2.50 0.0	0.00 0.00			
12	Sprinkler ---	---	80.00 0.0	92.56 ---	2.50 0.0	0.00 0.00			
13	Sprinkler ---	---	80.00 0.0	77.36 ---	2.50 0.0	0.00 0.00			
14	Sprinkler ---	---	80.00 0.0	83.69 ---	2.50 0.0	0.00 0.00			
15	Sprinkler ---	---	80.00 0.0	87.97 ---	2.50 0.0	0.00 0.00			
16	Sprinkler ---	---	80.00 0.0	95.10 ---	2.50 0.0	0.00 0.00			

Fire - Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell				Elite Software Development, Inc. CANU-GARAZA Page 4					
Fire Sprinkler Input Data									
Node Input Data (cont'd)									
Node No.	Node Description Branch Description	Area Group Branch Dia. (cm)	Sprinkler KFactor (Km) Branch Len. (m)	Pressure Estimate (kPa) Branch Stnd Fittings	Node Elev (m) Branch Non- Snd Fittings (m)	Non-Sprinkler Flow (Lpm) Branch Sprk KFactor (Km)			
17	No Discharge ---	---	N/A 0.0	101.13 ---	2.40 0.0	0.00 0.00			
18	No Discharge ---	---	N/A 0.0	91.00 ---	2.40 0.0	0.00 0.00			
19	No Discharge ---	---	N/A 0.0	89.16 ---	2.40 0.0	0.00 0.00			
20	No Discharge ---	---	N/A 0.0	80.16 ---	2.40 0.0	0.00 0.00			
21	No Discharge ---	---	N/A 0.0	98.47 ---	2.40 0.0	0.00 0.00			
22	No Discharge ---	---	N/A 0.0	77.53 ---	2.40 0.0	0.00 0.00			
23	No Discharge ---	---	N/A 0.0	71.85 ---	2.40 0.0	0.00 0.00			
24	No Discharge ---	---	N/A 0.0	93.37 ---	2.40 0.0	0.00 0.00			
25	No Discharge ---	---	N/A 0.0	73.46 ---	2.40 0.0	0.00 0.00			
26	No Discharge ---	---	N/A 0.0	68.06 ---	2.40 0.0	0.00 0.00			
27	No Discharge ---	---	N/A 0.0	94.48 ---	2.40 0.0	0.00 0.00			
28	No Discharge ---	---	N/A 0.0	72.15 ---	2.40 0.0	0.00 0.00			
29	No Discharge ---	---	N/A 0.0	64.11 ---	2.40 0.0	0.00 0.00			
30	No Discharge ---	---	N/A 0.0	86.55 ---	2.40 0.0	0.00 0.00			
31	No Discharge ---	---	N/A 0.0	66.01 ---	2.40 0.0	0.00 0.00			
32	No Discharge ---	---	N/A 0.0	58.62 ---	2.40 0.0	0.00 0.00			
33	No Discharge ---	---	N/A 0.0	111.54 ---	2.40 0.0	0.00 0.00			

Wednesday, January 3, 2024, 4:47 PM

Fire - Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell				Elite Software Development, Inc. CANU-GARAZA Page 5					
Fire Sprinkler Input Data									
Node Input Data (cont'd)									
Node No.	Node Description Branch Description	Area Group Branch Dia. (cm)	Sprinkler KFactor (Km) Branch Len. (m)	Pressure Estimate (kPa) Branch Stnd Fittings	Node Elev (m) Branch Non-Snd Fittings (m)	Non-Sprinkler Flow (Lpm) Branch Spk KFactor (Km)			
34	No Discharge ---	---	N/A 0.0	137.62 ---	2.40 0.0	0.00 0.00			
35	No Discharge ---	---	N/A 0.0	112.10 ---	2.40 0.0	0.00 0.00			
36	No Discharge ---	---	N/A 0.0	118.22 ---	2.40 0.0	0.00 0.00			
37	No Discharge ---	---	N/A 0.0	133.86 ---	2.40 0.0	0.00 0.00			
38	No Discharge ---	---	N/A 0.0	165.59 ---	2.40 0.0	0.00 0.00			
39	No Discharge ---	---	N/A 0.0	196.43 ---	0.00 0.0	0.00 0.00			
40	No Discharge ---	---	N/A 0.0	210.66 ---	0.00 0.0	0.00 0.00			

Fire - Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell								Elite Software Development, Inc. CANU-GARAZA Page 6					
Fire Sprinkler Input Data													
Pipe Input Data													
Beg. Node	End. Node	Pipe Description	Nominal Diameter (mm)	Type Group	Fitting Data	Nominal Length (m)	Fitting Length (m)	Total Length (m)	CFactor (gpm/inch-psi)				
40	39	SCHED 40 WET STEEL	101.600	0	TGC	2.00	21.41	23.41	120				
39	38	SCHED 40 WET STEEL	101.600	0	EG	2.40	9.66	12.06	120				
38	34	SCHED 40 WET STEEL	101.600	0	2E3TG	21.00	24.99	45.99	120				
34	33	SCHED 40 WET STEEL	50.800	0	T	8.10	3.05	11.15	120				
33	30	SCHED 40 WET STEEL	31.750	0	E	4.70	0.91	5.61	120				
34	37	SCHED 40 WET STEEL	63.500	0		1.30	0.00	1.30	120				
37	36	SCHED 40 WET STEEL	50.800	0		3.55	0.00	3.55	120				
36	35	SCHED 40 WET STEEL	50.800	0		2.40	0.00	2.40	120				
35	24	SCHED 40 WET STEEL	31.750	0		3.80	0.00	3.80	120				
30	31	SCHED 40 WET STEEL	25.400	0		2.85	0.00	2.85	120				
31	32	SCHED 40 WET STEEL	25.400	0		3.86	0.00	3.86	120				
33	27	SCHED 40 WET STEEL	31.750	0	T	1.70	1.83	3.53	120				
27	28	SCHED 40 WET STEEL	25.400	0		2.85	0.00	2.85	120				
28	29	SCHED 40 WET STEEL	25.400	0		3.86	0.00	3.86	120				
37	17	SCHED 40 WET STEEL	25.400	0	T	1.50	1.52	3.02	120				
17	18	SCHED 40 WET STEEL	25.400	0		3.50	0.00	3.50	120				
36	19	SCHED 40 WET STEEL	25.400	0	T	1.50	1.52	3.02	120				
19	20	SCHED 40 WET STEEL	25.400	0		3.50	0.00	3.50	120				
35	21	SCHED 40 WET STEEL	31.750	0	T	0.80	1.83	2.63	120				
21	22	SCHED 40 WET STEEL	25.400	0		2.45	0.00	2.45	120				
22	23	SCHED 40 WET STEEL	25.400	0		2.45	0.00	2.45	120				
24	25	SCHED 40 WET STEEL	25.400	0		2.45	0.00	2.45	120				
25	26	SCHED 40 WET STEEL	25.400	0		2.45	0.00	2.45	120				
32	1	SCHED 40 WET STEEL	25.400	0	E	0.10	0.61	0.71	120				
31	2	SCHED 40 WET STEEL	25.400	0	T	0.10	1.52	1.62	120				
30	3	SCHED 40 WET STEEL	25.400	0	T	0.10	1.52	1.62	120				

Wednesday, January 3, 2024, 4:47 PM

Fire - Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell								Elite Software Development, Inc. CANU-GARAZA Page 7					
Fire Sprinkler Input Data													
Pipe Input Data (cont'd)													
Beg. Node	End. Node	Pipe Description	Nominal Diameter (mm)	Type Group	Fitting Data	Nominal Length (m)	Fitting Length (m)	Total Length (m)	CFactor (gpm/inch-psi)				
29	4	SCHED 40 WET STEEL	25.400	0	E	0.10	0.61	0.71	120				
28	5	SCHED 40 WET STEEL	25.400	0	T	0.10	1.52	1.62	120				
27	6	SCHED 40 WET STEEL	25.400	0	T	0.20	1.52	1.72	120				
26	7	SCHED 40 WET STEEL	25.400	0	E	0.10	0.61	0.71	120				
25	8	SCHED 40 WET STEEL	25.400	0	T	0.10	1.52	1.62	120				
24	9	SCHED 40 WET STEEL	25.400	0	T	0.10	1.52	1.62	120				
23	10	SCHED 40 WET STEEL	25.400	0	E	0.10	0.61	0.71	120				
22	11	SCHED 40 WET STEEL	25.400	0	T	0.10	1.52	1.62	120				
21	12	SCHED 40 WET STEEL	25.400	0	T	0.10	1.52	1.62	120				
20	13	SCHED 40 WET STEEL	25.400	0	E	0.10	0.61	0.71	120				
19	14	SCHED 40 WET STEEL	25.400	0	T	0.10	1.52	1.62	120				
18	15	SCHED 40 WET STEEL	25.400	0	E	0.10	0.61	0.71	120				
17	16	SCHED 40 WET STEEL	25.400	0	T	0.10	1.52	1.62	120				

Fire Sprinkler Output Data							
Overall Node Groupings Output Data							
Pipe Segment Beg. Node	End. Node	Pipe Type Group	Pipe Flow Rate (Lpm)	Sprinkler Flow At Beg. Node (Lpm)	Non-Sprinkler Flow Out (+) (Lpm)	In (-) (Lpm)	Beg. Node Residual Pressure (kPa)
1	32	0	-59.99	59.99	0.00	0.00	56.29
2	31	0	-62.79	62.79	0.00	0.00	61.65
3	30	0	-72.06	72.06	0.00	0.00	81.20
4	29	0	-62.79	62.79	0.00	0.00	61.65
5	28	0	-65.69	65.70	0.00	0.00	67.50
6	27	0	-75.22	75.22	0.00	0.00	88.49
7	26	0	-64.73	64.73	0.00	0.00	65.52
8	25	0	-66.30	66.30	0.00	0.00	68.74
9	24	0	-74.88	74.89	0.00	0.00	87.70
10	23	0	-66.53	66.53	0.00	0.00	69.22
11	22	0	-68.14	68.14	0.00	0.00	72.61
12	21	0	-76.93	76.93	0.00	0.00	92.56
13	20	0	-70.33	70.33	0.00	0.00	77.36
14	19	0	-73.15	73.15	0.00	0.00	83.69
15	18	0	-75.00	75.00	0.00	0.00	87.97
16	17	0	-77.98	77.98	0.00	0.00	95.10
17	16	0	77.98	0.00	0.00	0.00	101.13
17	37	0	-152.98				
17	18	0	75.00				
18	15	0	75.00	0.00	0.00	0.00	91.00
18	17	0	-75.00				
19	14	0	73.15	0.00	0.00	0.00	89.16
19	36	0	-143.48				
19	20	0	70.33				
20	13	0	70.33	0.00	0.00	0.00	80.16
20	19	0	-70.33				
21	12	0	76.93	0.00	0.00	0.00	98.47
21	35	0	-211.60				
21	22	0	134.67				
22	11	0	68.14	0.00	0.00	0.00	77.53
							0.00002

Wednesday, January 3, 2024, 4:47 PM

Fire - Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell					Elite Software Development, Inc. CANU-GARAZA Page 9						
Fire Sprinkler Output Data											
Overall Node Groupings Output Data (cont'd)											
Pipe Segment Beg. Node	Pipe Segment End. Node	Pipe Type Group	Pipe Flow Rate (Lpm)	Sprinkler Flow At Beg. Node (Lpm)	Non-Sprinkler Flow Out (+) (Lpm)	Non-Sprinkler Flow In (-) (Lpm)	Beg. Node Residual Pressure (kPa)	Imbalance Flow At Beg. Node (Lpm)			
22	21	0	-134.67								
22	23	0	66.53								
23	10	0	66.53	0.00	0.00	0.00	71.85	0.00001			
23	22	0	-66.53								
24	9	0	74.88	0.00	0.00	0.00	93.37	0.00001			
24	35	0	-205.91								
24	25	0	131.02								
25	8	0	66.30	0.00	0.00	0.00	73.46	0.00002			
25	24	0	-131.02								
25	26	0	64.73								
26	7	0	64.73	0.00	0.00	0.00	68.06	0.00002			
26	25	0	-64.73								
27	6	0	75.22	0.00	0.00	0.00	94.48	0.00000			
27	33	0	-203.70								
27	28	0	128.48								
28	5	0	65.69	0.00	0.00	0.00	72.15	0.00002			
28	27	0	-128.48								
28	29	0	62.79								
29	4	0	62.79	0.00	0.00	0.00	64.11	0.00001			
29	28	0	-62.79								
30	3	0	72.06	0.00	0.00	0.00	86.55	0.00001			
30	33	0	-194.83								
30	31	0	122.78								
31	2	0	62.79	0.00	0.00	0.00	66.01	0.00001			
31	30	0	-122.78								
31	32	0	59.99								
32	1	0	59.99	0.00	0.00	0.00	58.62	-0.00720			
32	31	0	-59.99								
33	27	0	203.70	0.00	0.00	0.00	111.54	0.00001			
33	30	0	194.83								
33	34	0	-398.54								
34	33	0	398.54	0.00	0.00	0.00	137.62	0.00013			
34	38	0	-1112.51								
34	37	0	713.97								
35	21	0	211.60	0.00	0.00	0.00	112.10	0.00004			
35	24	0	205.91								
35	36	0	-417.51								
36	19	0	143.48	0.00	0.00	0.00	118.22	0.00003			

Wednesday, January 3, 2024, 4:47 PM

Fire Sprinkler Output Data							
Overall Node Groupings Output Data (cont'd)							
Pipe Segment Beg. Node	End. Node	Pipe Type Group	Pipe Flow Rate (Lpm)	Sprinkler Flow At Beg. Node (Lpm)	Non-Sprinkler Flow Out (+) (Lpm)	In (-) (Lpm)	Beg. Node Residual Pressure (kPa)
36	35	0	417.51				
36	37	0	-560.99				
37	17	0	152.98	0.00	0.00	0.00	133.86 -0.00010
37	34	0	-713.97				
37	36	0	560.99				
38	34	0	1112.51	0.00	0.00	0.00	165.59 -0.00013
38	39	0	-1112.51				
39	38	0	1112.51	0.00	0.00	0.00	196.43 0.00007
39	40	0	-1112.51				
40	39	0	1112.51	0.00	0.00	1112.507 96313041	210.66

Fire - Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell							Elite Software Development, Inc. CANU-GARAZA Page 11							
Fire Sprinkler Output Data														
Overall Pipe Output Data														
Beg. End. Node	Nodal KFactor (Km)	Elevation (m)	Spk/Hose Discharge (Lpm)	Residual Pressure (kPa)	Nom. Dia. Inside Dia. C-Value	q (Lpm) Q (Lpm) Velocity (m/s)	F. L./m (kPa/m) Fittings Type-Grp	Pipe-Len. Fit-Len. Tot-Len. (m)	PF-(kPa) PE-(kPa) PT-(kPa)					
17	0.00	2.40	0.00	101.15	25.40	77.98	3.11058	0.10	5.051					
16	80.04	2.50	77.98	95.08	26.670	77.98	T	1.52	0.979					
SCHED 40 WET STEEL														
17	0.00	2.40	0.00	101.15	25.40	0.00	2.89421	3.50	10.130					
18	0.00	2.40	0.00	91.01	26.670	74.99	—	0.00	0.000					
SCHED 40 WET STEEL														
18	0.00	2.40	0.00	91.01	25.40	75.00	2.89421	0.10	2.054					
15	80.04	2.50	74.99	87.98	26.670	74.99	E	0.61	0.979					
SCHED 40 WET STEEL														
19	0.00	2.40	0.00	89.15	25.40	73.15	2.76370	0.10	4.488					
14	80.04	2.50	73.17	83.70	26.670	73.17	T	1.52	0.979					
SCHED 40 WET STEEL														
19	0.00	2.40	0.00	89.15	25.40	0.00	2.56981	3.50	8.994					
20	0.00	2.40	0.00	80.19	26.670	70.33	—	0.00	0.000					
SCHED 40 WET STEEL														
20	0.00	2.40	0.00	80.19	25.40	70.33	2.56981	0.10	1.823					
13	80.04	2.50	70.33	77.36	26.670	70.33	E	0.61	0.979					
SCHED 40 WET STEEL														
21	0.00	2.40	0.00	98.46	25.40	76.93	3.03362	0.10	4.927					
12	80.04	2.50	76.92	92.60	26.670	76.92	T	1.52	0.979					
SCHED 40 WET STEEL														
21	0.00	2.40	0.00	98.46	25.40	0.00	8.54770	2.45	20.942					
22	0.00	2.40	0.00	77.50	26.670	134.68	—	0.00	0.000					
SCHED 40 WET STEEL														
22	0.00	2.40	0.00	77.50	25.40	68.14	2.42353	0.10	3.936					
11	80.04	2.50	68.14	72.60	26.670	68.14	T	1.52	0.979					
SCHED 40 WET STEEL														
22	0.00	2.40	0.00	77.50	25.40	0.00	2.31868	2.45	5.681					
23	0.00	2.40	0.00	71.84	26.670	66.55	—	0.00	0.000					
SCHED 40 WET STEEL														
23	0.00	2.40	0.00	71.84	25.40	66.53	2.31868	0.10	1.645					
10	80.04	2.50	66.55	69.22	26.670	66.55	E	0.61	0.979					
SCHED 40 WET STEEL														
24	0.00	2.40	0.00	93.36	25.40	74.89	2.88588	0.10	4.687					
9	80.04	2.50	74.87	87.70	26.670	74.87	T	1.52	0.979					
SCHED 40 WET STEEL														


Fire - Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell							Elite Software Development, Inc. CANU-GARAZA Page 12							
Fire Sprinkler Output Data														
Overall Pipe Output Data (cont'd)														
Beg. End. Node	Nodal KFactor (Km)	Elevation (m)	Spk/Hose Discharge (Lpm)	Residual Pressure (kPa)	Nom. Dia. Inside Dia. C-Value	q (Lpm) Q (Lpm) Velocity (m/s)	F. L./m (kPa/m) Fittings Type-Grp	Pipe-Len. Fit-Len. Tot-Len. (m)	PF-(kPa) PE-(kPa) PT-(kPa)					
24	0.00	2.40	0.00	93.36	25.40	0.00	8.12449	2.45	19.905					
25	0.00	2.40	0.00	73.43	26.670	131.01	—	0.00	0.000					
	SCHED 40 WET STEEL					120	3.92	0	2.45	19.905				
25	0.00	2.40	0.00	73.43	25.40	66.30	2.30373	0.10	3.741					
8	80.04	2.50	66.28	68.74	26.670	66.28	T	1.52	0.979					
	SCHED 40 WET STEEL					120	1.98	0	1.62	4.721				
25	0.00	2.40	0.00	73.43	25.40	0.00	2.20369	2.45	5.399					
26	0.00	2.40	0.00	68.05	26.670	64.73	—	0.00	0.000					
	SCHED 40 WET STEEL					120	1.94	0	2.45	5.399				
26	0.00	2.40	0.00	68.05	25.40	64.73	2.20369	0.10	1.564					
7	80.04	2.50	64.73	65.50	26.670	64.73	E	0.61	0.979					
	SCHED 40 WET STEEL					120	1.94	0	0.71	2.543				
27	0.00	2.40	0.00	94.46	25.40	75.22	2.90984	0.20	5.016					
6	80.04	2.50	75.21	88.46	26.670	75.21	T	1.52	0.979					
	SCHED 40 WET STEEL					120	2.25	0	1.73	5.996				
27	0.00	2.40	0.00	94.46	25.40	0.00	7.83543	2.85	22.330					
28	0.00	2.40	0.00	72.12	26.670	128.47	—	0.00	0.000					
	SCHED 40 WET STEEL					120	3.84	0	2.85	22.330				
28	0.00	2.40	0.00	72.12	25.40	65.70	2.26511	0.10	3.678					
5	80.04	2.50	65.71	67.50	26.670	65.71	T	1.52	0.979					
	SCHED 40 WET STEEL					120	1.96	0	1.62	4.658				
28	0.00	2.40	0.00	72.12	25.40	0.00	2.08320	3.86	8.041					
29	0.00	2.40	0.00	64.12	26.670	62.80	—	0.00	0.000					
	SCHED 40 WET STEEL					120	1.88	0	3.86	8.041				
29	0.00	2.40	0.00	64.12	25.40	62.79	2.08320	0.10	1.478					
4	80.04	2.50	62.80	61.64	26.670	62.80	E	0.61	0.979					
	SCHED 40 WET STEEL					120	1.88	0	0.71	2.458				
30	0.00	2.40	0.00	86.53	25.40	72.06	2.68751	0.10	4.364					
3	80.04	2.50	72.07	81.22	26.670	72.07	T	1.52	0.979					
	SCHED 40 WET STEEL					120	2.15	0	1.62	5.344				
30	0.00	2.40	0.00	86.53	25.40	0.00	7.20408	2.85	20.531					
31	0.00	2.40	0.00	65.98	26.670	122.80	—	0.00	0.000					
	SCHED 40 WET STEEL					120	3.67	0	2.85	20.531				
31	0.00	2.40	0.00	65.98	25.40	62.79	2.08310	0.10	3.383					
2	80.04	2.50	62.80	61.64	26.670	62.80	T	1.52	0.979					
	SCHED 40 WET STEEL					120	1.88	0	1.62	4.362				

Fire - Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell							Elite Software Development, Inc. CANU-GARAZA Page 13							
Fire Sprinkler Output Data														
Overall Pipe Output Data (cont'd)														
Beg. End. Node	Nodal KFactor (Km)	Elevation (m)	Spk/Hose Discharge (Lpm)	Residual Pressure (kPa)	Nom. Dia. Inside Dia. C-Value	q (Lpm) Q (Lpm) Velocity (m/s)	F. L./m Fittings Type-Grp	Pipe-Len. Fit-Len. Tot-Len. (m)	PF-(kPa) PE-(kPa) PT-(kPa)					
31	0.00	2.40	0.00	65.98	25.40	0.00	1.91486	3.86	7.391					
32	0.00	2.40	0.00	58.61	26.670	60.00	—	0.00	0.000					
	SCHED 40 WET STEEL					120	1.79	0	3.86	7.391				
32	0.00	2.40	0.00	58.61	25.40	59.99	1.91443	0.10	1.358					
1	80.04	2.50	60.00	56.26	26.670	60.00	E	0.61	0.979					
	SCHED 40 WET STEEL					120	1.79	0	0.71	2.338				
33	0.00	2.40	0.00	111.56	31.75	0.00	4.83428	1.70	17.059					
27	0.00	2.40	0.00	94.46	35.052	203.69	T	1.83	0.000					
	SCHED 40 WET STEEL					120	3.52	0	3.53	17.059				
33	0.00	2.40	0.00	111.56	31.75	0.00	4.45219	4.70	24.996					
30	0.00	2.40	0.00	86.53	35.052	194.83	E	0.91	0.000					
	SCHED 40 WET STEEL					120	3.36	0	5.61	24.996				
34	0.00	2.40	0.00	137.62	50.80	0.00	2.33939	8.10	26.080					
33	0.00	2.40	0.00	111.56	52.578	398.52	T	3.05	0.000					
	SCHED 40 WET STEEL					120	3.07	0	11.15	26.080				
34	0.00	2.40	0.00	137.62	63.50	0.00	2.89543	1.30	3.764					
37	0.00	2.40	0.00	133.83	62.738	713.99	—	0.00	0.000					
	SCHED 40 WET STEEL					120	3.85	0	1.30	3.764				
35	0.00	2.40	0.00	112.11	31.75	0.00	5.18683	0.80	13.636					
21	0.00	2.40	0.00	98.46	35.052	211.60	T	1.83	0.000					
	SCHED 40 WET STEEL					120	3.65	0	2.63	13.636				
35	0.00	2.40	0.00	112.11	31.75	0.00	4.93155	3.80	18.740					
24	0.00	2.40	0.00	93.36	35.052	205.92	—	0.00	0.000					
	SCHED 40 WET STEEL					120	3.56	0	3.80	18.740				
36	0.00	2.40	0.00	118.25	25.40	0.00	9.61166	1.50	29.065					
19	0.00	2.40	0.00	89.15	26.670	143.50	T	1.52	0.000					
	SCHED 40 WET STEEL					120	4.29	0	3.02	29.065				
36	0.00	2.40	0.00	118.25	50.80	0.00	2.54958	2.40	6.119					
35	0.00	2.40	0.00	112.11	52.578	417.52	—	0.00	0.000					
	SCHED 40 WET STEEL					120	3.22	0	2.40	6.119				
37	0.00	2.40	0.00	133.83	25.40	0.00	10.82144	1.50	32.723					
17	0.00	2.40	0.00	101.15	26.670	152.97	T	1.52	0.000					
	SCHED 40 WET STEEL					120	4.57	0	3.02	32.723				
37	0.00	2.40	0.00	133.83	50.80	0.00	4.40380	3.55	15.634					
36	0.00	2.40	0.00	118.25	52.578	560.99	—	0.00	0.000					
	SCHED 40 WET STEEL					120	4.32	0	3.55	15.634				

Fire - Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell							Elite Software Development, Inc. CANU-GARAZA Page 14							
Fire Sprinkler Output Data														
Overall Pipe Output Data (cont'd)														
Beg. End. Node	Nodal KFactor (Km)	Elevation (m)	Spk/Hose Discharge (Lpm)	Residual Pressure (kPa)	Nom. Dia. Inside Dia. C-Value	q (Lpm) Q (Lpm) Velocity (m/s)	F. L./m Fittings Type-Grp	Pipe-Len. Fit-Len. Tot-Len. (m)	PF-(kPa) PE-(kPa) PT-(kPa)					
38	0.00	2.40	0.00	165.61	101.60	0.00	0.60804	21.00	27.966					
34	0.00	2.40	0.00	137.62	102.362	1112.51	2E3TG	24.99	0.000					
SCHED 40 WET STEEL														
39	0.00	0.00	0.00	196.43	101.60	0.00	0.60804	2.40	7.332					
38	0.00	2.40	0.00	165.61	102.362	1112.51	EG	9.66	23.507					
SCHED 40 WET STEEL														
40	0.00	0.00	0.00	210.63	101.60	0.00	0.60804	2.00	14.235					
39	0.00	0.00	0.00	196.43	102.362	1112.51	TGC	21.41	0.000					
SCHED 40 WET STEEL														
						120	2.26	0	23.41	14.235				

Fire - Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell				Elite Software Development, Inc. CANU-GARAZA Page 15						
Fire Sprinkler Output Data										
Overall Sprinkler Output Data										
Flowing Sprinkler Node No.	Area Group Code	Sprinkler KFactor (Km)	Sprinkler Elevation (m)	Residual Pressure (kPa)	Flowing Area (m²)	Flowing Density (Lpm/m²)	Sprinkler Discharge (Lpm)			
1		80.00	2.50	56.29	12.00	4.999	59.99			
Sub Totals For Non-Group					12.00	4.999	59.99			
2		80.00	2.50	61.65	12.00	5.232	62.79			
Sub Totals For Non-Group					12.00	5.232	62.79			
3		80.00	2.50	81.20	12.00	6.005	72.06			
Sub Totals For Non-Group					12.00	6.005	72.06			
4		80.00	2.50	61.65	12.00	5.232	62.79			
Sub Totals For Non-Group					12.00	5.232	62.79			
5		80.00	2.50	67.50	12.00	5.475	65.70			
Sub Totals For Non-Group					12.00	5.475	65.70			
6		80.00	2.50	88.49	12.00	6.268	75.22			
Sub Totals For Non-Group					12.00	6.268	75.22			
7		80.00	2.50	65.52	12.00	5.394	64.73			
Sub Totals For Non-Group					12.00	5.394	64.73			
8		80.00	2.50	68.74	12.00	5.525	66.30			
Sub Totals For Non-Group					12.00	5.525	66.30			
9		80.00	2.50	87.70	12.00	6.241	74.89			
Sub Totals For Non-Group					12.00	6.241	74.89			
10		80.00	2.50	69.22	12.00	5.544	66.53			
Sub Totals For Non-Group					12.00	5.544	66.53			
11		80.00	2.50	72.61	12.00	5.678	68.14			
Sub Totals For Non-Group					12.00	5.678	68.14			
12		80.00	2.50	92.56	12.00	6.411	76.93			
Sub Totals For Non-Group					12.00	6.411	76.93			
13		80.00	2.50	77.36	12.00	5.861	70.33			
Sub Totals For Non-Group					12.00	5.861	70.33			
14		80.00	2.50	83.69	12.00	6.096	73.15			
Sub Totals For Non-Group					12.00	6.096	73.15			
15		80.00	2.50	87.97	12.00	6.250	75.00			
Sub Totals For Non-Group					12.00	6.250	75.00			
16		80.00	2.50	95.10	12.00	6.499	77.98			
Sub Totals For Non-Group					12.00	6.499	77.98			
Totals For All Groups					192.00	5.794	1112.54			

Fire - Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell			Elite Software Development, Inc. CANU-GARAZA Page 16
Fire Sprinkler Output Summary			
Hydraulically Most Demanding Sprinkler Node			
HMD Sprinkler Node Number:	1	HMD Actual Residual Pressure:	56.29 kPa
HMD Actual Flow:	59.99 Lpm		
Sprinkler Summary			
Sprinkler System Type:	Wet	Specified Area Of Application:	144.00 m ²
Minimum Desired Density:	4.999 Lpm/m ²	Application Average Density:	7.726 Lpm/m ²
Application Average Area Per Sprinkler:	9.00 m ²	Sprinkler Flow:	1112.54 Lpm
Average Sprinkler Flow:	69.53 Lpm		
Flow Velocity And Imbalance Summary			
Maximum Flow Velocity (In Pipe 17 - 37)	4.57 m/sec	Maximum Velocity Pressure (In Pipe 17 - 37)	10.44 kPa
Allowable Maximum Nodal Pressure Imbalance:	1.5003 kPa	Actual Maximum Nodal Pressure Imbalance:	0.0058 kPa
Actual Average Nodal Pressure Imbalance:	0.0011 kPa	Actual Maximum Nodal Flow Imbalance:	-0.0072 Lpm
Actual Average Nodal Flow Imbalance:	0.0010 Lpm		
Overall Network Summary			
Number Of Unique Pipe Sections:	39	Number Of Flowing Sprinklers:	16
Pipe System Water Volume:	273.13 L		
Sprinkler Flow:	1112.54 Lpm	Non-Sprinkler Flow:	0.00 Lpm
Minimum Required Residual Pressure At System Inflow Node:	210.66 kPa	Demand Flow At System Inflow Node:	1112.51 Lpm



PRORAČUN – 6 – ti SPRAT

Fire - Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell			Elite Software Development, Inc. CANU 6-ti sprat Page 2
General Project Data Report			
General Data			
Project Title:	CANU 6-ti sprat	Project File Name:	CANU 6-TI SPRAT..fwi
Designed By:		Date:	1/3/2024
Code Reference:		Approving Agency:	
Client Name:		Phone:	
Address:		City, State Zip Code:	
Company Name:		Representative:	
Company Address:		City And State:	
Phone:		Building Owner:	
Building Name:		Phone at Building:	
Contact at Building:		City, State Zip Code:	
Address Of Building:			
Project Data			
Description Of Hazard:	OH1	Sprinkler System Type:	Wet
Design Area Of Water Application:	72 m ²	Maximum Area Per Sprinkler:	12 m ²
Default Sprinkler K-Factor:	80.00 Km	Default Pipe Material:	SCHED 40 WET STEEL
Inside Hose Stream Allowance:	0.00 Lpm	Outside Hose Stream Allowance:	0.00 Lpm
In Rack Sprinkler Allowance:	0.00 Lpm		
Sprinkler Specifications			
Make:	VIKING	Model:	MX5
Size:	DN15	Temperature Rating:	67.79 C
Water Supply Test Data			
Source Of Information:			
Test Hydrant ID:		Date Of Test:	
Hydrant Elevation:	0 m	Static Pressure:	0.00 kPa
Test Flow Rate:	0.00 Lpm	Test Residual Pressure:	0.00 kPa
Calculated System Flow Rate:	597.74 Lpm	Calculated Inflow Residual Pressure:	465.34 kPa
Calculation Project Data			
Calculation Mode:	Demand		
HMD Minimum Residual Pressure:	56.00 kPa	Minimum Desired Flow Density:	5.00 Lpm/m ²
Number Of Active Nodes:	26		
Number Of Active Pipes:	25	Number Of Inactive Pipes:	0
Number Of Active Sprinklers:	9	Number Of Inactive Sprinklers:	0

Thursday, January 11, 2024, 4:23 PM

Fire Sprinkler Input Data						
Node Input Data						
Node No.	Node Description Branch Description	Area Group Branch Dia. (cm)	Sprinkler KFactor (Km) Branch Len. (m)	Pressure Estimate (kPa) Branch Stnd Fittings	Node Elev (m) Branch Non-Stnd Fittings (m)	Non-Sprinkler Flow (Lpm) Branch Sprk KFactor (Km)
1	Sprinkler ---	---	80.00 0.0	56.29 ---	29.80 0.0	0.00 0.00
2	Sprinkler ---	---	80.00 0.0	58.71 ---	29.80 0.0	0.00 0.00
3	Sprinkler ---	---	80.00 0.0	74.63 ---	29.80 0.0	0.00 0.00
4	Sprinkler ---	---	80.00 0.0	59.81 ---	29.80 0.0	0.00 0.00
5	Sprinkler ---	---	80.00 0.0	62.38 ---	29.80 0.0	0.00 0.00
6	Sprinkler ---	---	80.00 0.0	83.85 ---	29.80 0.0	0.00 0.00
7	Sprinkler ---	---	80.00 0.0	69.26 ---	29.80 0.0	0.00 0.00
8	Sprinkler ---	---	80.00 0.0	72.05 ---	29.80 0.0	0.00 0.00
9	Sprinkler ---	---	80.00 0.0	87.27 ---	29.80 0.0	0.00 0.00
10	No Discharge ---	---	N/A 0.0	127.58 ---	30.00 0.0	0.00 0.00
11	No Discharge ---	---	N/A 0.0	107.69 ---	30.00 0.0	0.00 0.00
12	No Discharge ---	---	N/A 0.0	101.43 ---	30.00 0.0	0.00 0.00
13	No Discharge ---	---	N/A 0.0	125.15 ---	30.00 0.0	0.00 0.00
14	No Discharge ---	---	N/A 0.0	93.32 ---	30.00 0.0	0.00 0.00
15	No Discharge ---	---	N/A 0.0	87.65 ---	30.00 0.0	0.00 0.00
16	No Discharge ---	---	N/A 0.0	111.51 ---	30.00 0.0	0.00 0.00

Thursday, January 11, 2024, 4:23 PM

Fire Sprinkler Input Data						
Node Input Data (cont'd)		Area Group	Sprinkler	Pressure	Node Elev (m)	Non-Sprinkler
Node No.	Node Description	Branch Dia. (cm)	KFactor (Km)	Estimate (kPa)	Branch Non-Stnd Fittings (m)	Flow (Lpm)
	Branch Description		Branch Len. (m)	Branch Stnd Fittings	Branch Non-Stnd Fittings (m)	Branch Sprk KFactor (Km)
17	No Discharge	---	N/A	87.85	30.00	0.00
	---	0.000	0.0	---	0.0	0.00
18	No Discharge	---	N/A	82.49	30.00	0.00
	---	0.000	0.0	---	0.0	0.00
19	No Discharge	---	N/A	128.22	30.00	0.00
	---	0.000	0.0	---	0.0	0.00
20	No Discharge	---	N/A	133.68	30.00	0.00
	---	0.000	0.0	---	0.0	0.00
21	No Discharge	---	N/A	133.74	30.00	0.00
	---	0.000	0.0	---	0.0	0.00
22	No Discharge	---	N/A	142.58	30.00	0.00
	---	0.000	0.0	---	0.0	0.00
23	No Discharge	---	N/A	427.04	2.40	0.00
	---	0.000	0.0	---	0.0	0.00
24	No Discharge	---	N/A	435.00	2.40	0.00
	---	0.000	0.0	---	0.0	0.00
25	No Discharge	---	N/A	460.83	0.00	0.00
	---	0.000	0.0	---	0.0	0.00
26	No Discharge	---	N/A	465.34	0.00	0.00
	---	0.000	0.0	---	0.0	0.00

Thursday, January 11, 2024, 4:23 PM

Fire Sprinkler Input Data							Elite Software Development, Inc. CANU 6-ti sprat Page 5		
Beg. Node	End. Node	Pipe Description	Nominal Diameter (mm)	Type Group	Fitting Data	Nominal Length (m)	Fitting Length (m)	Total Length (m)	CFactor (gpm/inch-psi)
26	25	SCHED 40 WET STEEL	101.600	0	TGC	2.00	21.41	23.41	120
25	24	SCHED 40 WET STEEL	101.600	0	EG	2.40	9.66	12.06	120
24	23	SCHED 40 WET STEEL	101.600	0	3E2T	20.00	21.34	41.34	120
23	22	SCHED 40 WET STEEL	101.600	0	E7T	27.60	45.72	73.32	120
22	21	SCHED 40 WET STEEL	101.600	0	5EG	30.00	15.85	45.85	120
21	20	SCHED 40 WET STEEL	101.600	0		2.40	0.00	2.40	120
20	19	SCHED 40 WET STEEL	25.400	0		0.64	0.00	0.64	120
20	10	SCHED 40 WET STEEL	25.400	0	T	0.60	1.52	2.12	120
21	13	SCHED 40 WET STEEL	50.800	0	T	0.80	3.05	3.85	120
19	11	SCHED 40 WET STEEL	25.400	0	E	1.80	0.61	2.41	120
11	12	SCHED 40 WET STEEL	25.400	0		2.70	0.00	2.70	120
13	16	SCHED 40 WET STEEL	31.750	0		3.20	0.00	3.20	120
13	14	SCHED 40 WET STEEL	25.400	0	T	2.75	1.52	4.27	120
14	15	SCHED 40 WET STEEL	25.400	0		2.80	0.00	2.80	120
16	17	SCHED 40 WET STEEL	25.400	0	E	2.75	0.61	3.36	120
17	18	SCHED 40 WET STEEL	25.400	0		2.80	0.00	2.80	120
18	1	SCHED 40 WET STEEL	25.400	0	E	0.20	14.51	14.71	120
17	2	SCHED 40 WET STEEL	25.400	0	T	0.20	15.42	15.62	120
16	3	SCHED 40 WET STEEL	25.400	0	T	0.20	15.42	15.62	120
15	4	SCHED 40 WET STEEL	25.400	0	E	0.20	14.51	14.71	120
14	5	SCHED 40 WET STEEL	25.400	0	T	0.20	15.42	15.62	120
13	6	SCHED 40 WET STEEL	25.400	0	T	0.20	15.42	15.62	120
12	7	SCHED 40 WET STEEL	25.400	0	E	0.20	14.51	14.71	120
11	8	SCHED 40 WET STEEL	25.400	0	T	0.20	15.42	15.62	120
10	9	SCHED 40 WET STEEL	25.400	0	E	0.20	14.51	14.71	120

Thursday, January 11, 2024, 4:23 PM

Fire Sprinkler Output Data								
Overall Node Groupings Output Data								
Pipe Beg. Node	Segment End. Node	Pipe Type Group	Pipe Flow Rate (Lpm)	Sprinkler Flow At Beg. Node (Lpm)	Non-Sprinkler Flow Out (+) (Lpm)	In (-) (Lpm)	Beg. Node Residual Pressure (kPa)	Imbalance Flow At Beg. Node (Lpm)
1	18	0	-59.99	59.99	0.00	0.00	56.29	
2	17	0	-61.27	61.27	0.00	0.00	58.71	0.00048
3	16	0	-69.08	69.08	0.00	0.00	74.63	-0.00008
4	15	0	-61.84	61.84	0.00	0.00	59.81	0.00123
5	14	0	-63.16	63.16	0.00	0.00	62.38	0.00137
6	13	0	-73.23	73.23	0.00	0.00	83.85	-0.00090
7	12	0	-66.55	66.55	0.00	0.00	69.26	-0.00015
8	11	0	-67.88	67.88	0.00	0.00	72.05	-0.00003
9	10	0	-74.70	74.70	0.00	0.00	87.27	-0.00148
10	9	0	74.70	0.00	0.00	0.00	127.58	0.00065
10	20	0	-74.70					
11	8	0	67.88	0.00	0.00	0.00	107.69	-0.00499
11	19	0	-134.43					
11	12	0	66.55					
12	7	0	66.55	0.00	0.00	0.00	101.43	0.00079
12	11	0	-66.55					
13	6	0	73.23	0.00	0.00	0.00	125.15	0.00432
13	21	0	-388.59					
13	16	0	190.35					
13	14	0	125.01					
14	5	0	63.16	0.00	0.00	0.00	93.32	-0.00764
14	13	0	-125.01					
14	15	0	61.84					
15	4	0	61.84	0.00	0.00	0.00	87.65	0.00010
15	14	0	-61.84					
16	3	0	69.08	0.00	0.00	0.00	111.51	0.00535
16	13	0	-190.35					
16	17	0	121.26					
17	2	0	61.27	0.00	0.00	0.00	87.85	-0.00310
17	16	0	-121.26					
17	18	0	59.99					
18	1	0	59.99	0.00	0.00	0.00	82.49	0.00080
18	17	0	-59.99					

Thursday, January 11, 2024, 4:23 PM

Fire Sprinkler Output Data							
Overall Node Groupings Output Data (cont'd)							
Pipe Beg. Node	Segment End. Node	Pipe Type Group	Pipe Flow Rate (Lpm)	Sprinkler Flow At Beg. Node (Lpm)	Non-Sprinkler Flow Out (+) (Lpm)	Non-Sprinkler Flow In (-) (Lpm)	Beg. Node Residual Pressure (kPa)
19	11	0	134.43	0.00	0.00	0.00	128.22
19	20	0	-134.43				-0.00125
20	10	0	74.70	0.00	0.00	0.00	133.68
20	19	0	134.43				0.00510
20	21	0	-209.14				
21	13	0	388.59	0.00	0.00	0.00	133.74
21	20	0	209.14				-0.00871
21	22	0	-597.74				
22	21	0	597.74	0.00	0.00	0.00	142.58
22	23	0	-597.74				0.00040
23	22	0	597.74	0.00	0.00	0.00	427.04
23	24	0	-597.74				-0.00053
24	23	0	597.74	0.00	0.00	0.00	435.00
24	25	0	-597.74				-0.00115
25	24	0	597.74	0.00	0.00	0.00	460.83
25	26	0	-597.74				0.00057
26	25	0	597.74	0.00	0.00	597.7406 3535471	465.34

Thursday, January 11, 2024, 4:23 PM

Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell							Elite Software Development, Inc. CANU 6-ti sprat Page 8							
Fire Sprinkler Output Data														
Overall Pipe Output Data														
Beg. End. Node	Nodal KFactor (Km)	Elevation (m)	Spk/Hose Discharge (Lpm)	Residual Pressure (kPa)	Norm. Dia. Inside Dia. C-Value	q (Lpm) Q (Lpm) Velocity (m/s)	F. L/m Fittings Type-Grp	Pipe-Len. Fit-Len. Tot-Len. (m)	PF-(kPa) PE-(kPa) PT-(kPa)					
10	0.00	30.00	0.00	127.55	25.40	74.70	2.87318 E	0.20	42.263					
9	80.04	29.80	74.68	87.29	26.670	74.72	— 0	14.51	-1.959					
	SCHED 40 WET STEEL					120	2.23	14.71	40.304					
11	0.00	30.00	0.00	107.70	25.40	67.88	2.40641 T	0.20	37.598					
8	80.04	29.80	67.87	72.05	26.670	67.87	— 0	15.42	-1.959					
	SCHED 40 WET STEEL					120	2.03	15.62	35.639					
11	0.00	30.00	0.00	107.70	25.40	0.00	2.31997 —	2.70	6.264					
12	0.00	30.00	0.00	101.42	26.670	66.55	— 0	0.00	0.000					
	SCHED 40 WET STEEL					120	1.99	2.70	6.264					
12	0.00	30.00	0.00	101.42	25.40	66.55	2.32002 E	0.20	34.127					
7	80.04	29.80	66.55	69.29	26.670	66.55	— 0	14.51	-1.959					
	SCHED 40 WET STEEL					120	1.99	14.71	32.168					
13	0.00	30.00	0.00	125.14	25.40	73.23	2.76884 T	0.20	43.260					
6	80.04	29.80	73.21	83.84	26.670	73.21	— 0	15.42	-1.959					
	SCHED 40 WET STEEL					120	2.19	15.62	41.301					
13	0.00	30.00	0.00	125.14	31.75	0.00	4.26444 —	3.20	13.647					
16	0.00	30.00	0.00	111.49	35.052	190.36	— 0	0.00	0.000					
	SCHED 40 WET STEEL					120	3.29	3.20	13.647					
13	0.00	30.00	0.00	125.14	25.40	0.00	7.44782 T	2.75	31.831					
14	0.00	30.00	0.00	93.36	26.670	124.99	— 0	1.52	0.000					
	SCHED 40 WET STEEL					120	3.74	4.27	31.831					
14	0.00	30.00	0.00	93.36	25.40	63.16	2.10584 T	0.20	32.902					
5	80.04	29.80	63.14	62.40	26.670	63.14	— 0	15.42	-1.959					
	SCHED 40 WET STEEL					120	1.89	15.62	30.943					
14	0.00	30.00	0.00	93.36	25.40	0.00	2.02559 —	2.80	5.671					
15	0.00	30.00	0.00	87.63	26.670	61.85	— 0	0.00	0.000					
	SCHED 40 WET STEEL					120	1.85	2.80	5.671					
15	0.00	30.00	0.00	87.63	25.40	61.84	2.02560 E	0.20	29.796					
4	80.04	29.80	61.85	59.85	26.670	61.85	— 0	14.51	-1.959					
	SCHED 40 WET STEEL					120	1.85	14.71	27.837					
16	0.00	30.00	0.00	111.49	25.40	69.08	2.48580 T	0.20	38.838					
3	80.04	29.80	69.08	74.60	26.670	69.08	— 0	15.42	-1.959					
	SCHED 40 WET STEEL					120	2.06	15.62	36.879					
16	0.00	30.00	0.00	111.49	25.40	0.00	7.04050 E	2.75	23.653					
17	0.00	30.00	0.00	87.84	26.670	121.28	— 0	0.61	0.000					
	SCHED 40 WET STEEL					120	3.62	3.36	23.653					

Fire Sprinkler Output Data							Overall Pipe Output Data (cont'd)			
Beg. End. Node	Nodal KFactor (Km)	Elevation (m)	Spk/Hose Discharge (Lpm)	Residual Pressure (kPa)	Norm. Dia. Inside Dia. C-Value	q (Lpm) Q (Lpm) Velocity (m/s)	F. L./m Fittings Type-Grp	Pipe-Len. Fit-Len. Tot-Len. (m)	PF-(kPa) PE-(kPa) PT-(kPa)	
17	0.00	30.00	0.00	87.84	25.40	61.27	1.99094	0.20	31.106	
2	80.04	29.80	61.28	58.67	26.670	61.28	T	15.42	-1.959	
SCHED 40 WET STEEL					120	1.83	0	15.62	29.148	
17	0.00	30.00	0.00	87.84	25.40	0.00	1.91481	2.80	5.361	
18	0.00	30.00	0.00	82.46	26.670	60.00	—	0.00	0.000	
SCHED 40 WET STEEL					120	1.79	0	2.80	5.361	
18	0.00	30.00	0.00	82.46	25.40	59.99	1.91485	0.20	28.167	
1	80.04	29.80	60.00	56.26	26.670	60.00	E	14.51	-1.959	
SCHED 40 WET STEEL					120	1.79	0	14.71	26.208	
19	0.00	30.00	0.00	128.24	25.40	0.00	8.52005	1.80	20.531	
11	0.00	30.00	0.00	107.70	26.670	134.42	E	0.61	0.000	
SCHED 40 WET STEEL					120	4.02	0	2.41	20.531	
20	0.00	30.00	0.00	133.69	25.40	0.00	2.87311	0.60	6.103	
10	0.00	30.00	0.00	127.55	26.670	74.72	T	1.52	0.000	
SCHED 40 WET STEEL					120	2.23	0	2.12	6.103	
20	0.00	30.00	0.00	133.69	25.40	0.00	8.52019	0.64	5.454	
19	0.00	30.00	0.00	128.24	26.670	134.42	—	0.00	0.000	
SCHED 40 WET STEEL					120	4.02	0	0.64	5.454	
21	0.00	30.00	0.00	133.76	50.80	0.00	2.23249	0.80	8.591	
13	0.00	30.00	0.00	125.14	52.578	388.60	T	3.05	0.000	
SCHED 40 WET STEEL					120	2.99	0	3.85	8.591	
21	0.00	30.00	0.00	133.76	101.60	0.00	0.02761	2.40	0.066	
20	0.00	30.00	0.00	133.69	102.362	209.14	—	0.00	0.000	
SCHED 40 WET STEEL					120	0.42	0	2.40	0.066	
22	0.00	30.00	0.00	142.58	101.60	0.00	0.19266	30.00	8.833	
21	0.00	30.00	0.00	133.76	102.362	597.74	SEG	15.85	0.000	
SCHED 40 WET STEEL					120	1.21	0	45.85	8.833	
23	0.00	2.40	0.00	427.06	101.60	0.00	0.19266	27.60	14.125	
22	0.00	30.00	0.00	142.58	102.362	597.74	E7T	45.72	270.334	
SCHED 40 WET STEEL					120	1.21	0	73.32	284.460	
24	0.00	2.40	0.00	434.99	101.60	0.00	0.19266	20.00	7.964	
23	0.00	2.40	0.00	427.06	102.362	597.74	3E2T	21.34	0.000	
SCHED 40 WET STEEL					120	1.21	0	41.34	7.964	
25	0.00	0.00	0.00	460.85	101.60	0.00	0.19266	2.40	2.323	
24	0.00	2.40	0.00	434.99	102.362	597.74	EG	9.66	23.507	
SCHED 40 WET STEEL					120	1.21	0	12.06	25.830	

Thursday, January 11, 2024, 4:23 PM

Fire - Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell							Elite Software Development, Inc. CANU 6-ti sprat Page 10							
Fire Sprinkler Output Data														
Overall Pipe Output Data (cont'd)														
Beg. End. Node	Nodal KFactor (Km)	Elevation (m)	Spk/Hose Discharge (Lpm)	Residual Pressure (kPa)	Nom. Dia. Inside Dia. C-Value	q (Lpm) Q (Lpm) Velocity (m/s)	F. L./m Fittings Type-Grp	Pipe-Len. Fit-Len. Tot-Len. (m)	PF-(kPa) PE-(kPa) PT-(kPa)					
26	0.00	0.00	0.00	465.33	101.60	0.00	0.19266 TGC	2.00 21.41 0	4.510 0.000 23.41					
25	0.00	0.00	0.00	460.85	102.362	597.74 1.21								
SCHED 40 WET STEEL														


Thursday, January 11, 2024, 4:23 PM

Fire - Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell					Elite Software Development, Inc. CANU 6-ti sprat Page 11					
Fire Sprinkler Output Data										
Overall Sprinkler Output Data										
Flowing Sprinkler Node No.	Area Group Code	Sprinkler KFactor (Km)	Sprinkler Elevation (m)	Residual Pressure (kPa)	Flowing Area (m²)	Flowing Density (Lpm/m²)	Sprinkler Discharge (Lpm)			
1		80.00	29.80	56.29	12.00	4.999	59.99			
Sub Totals For Non-Group					12.00	4.999	59.99			
2		80.00	29.80	58.71	12.00	5.106	61.27			
Sub Totals For Non-Group					12.00	5.106	61.27			
3		80.00	29.80	74.63	12.00	5.757	69.08			
Sub Totals For Non-Group					12.00	5.757	69.08			
4		80.00	29.80	59.81	12.00	5.154	61.84			
Sub Totals For Non-Group					12.00	5.154	61.84			
5		80.00	29.80	62.38	12.00	5.263	63.16			
Sub Totals For Non-Group					12.00	5.263	63.16			
6		80.00	29.80	83.85	12.00	6.102	73.23			
Sub Totals For Non-Group					12.00	6.102	73.23			
7		80.00	29.80	69.26	12.00	5.546	66.55			
Sub Totals For Non-Group					12.00	5.546	66.55			
8		80.00	29.80	72.05	12.00	5.657	67.88			
Sub Totals For Non-Group					12.00	5.657	67.88			
9		80.00	29.80	87.27	12.00	6.225	74.70			
Sub Totals For Non-Group					12.00	6.225	74.70			
Totals For All Groups				108.00	5.534	597.70				

Thursday, January 11, 2024, 4:23 PM

Fire - Fire Sprinkler Hydraulics Calculation Program pRejkEr Hell			Elite Software Development, Inc. CANU 6-ti sprat Page 12
Fire Sprinkler Output Summary			
Hydraulically Most Demanding Sprinkler Node			
HMD Sprinkler Node Number:	1	HMD Actual Residual Pressure:	56.29 kPa
HMD Actual Flow:	59.99 Lpm		
Sprinkler Summary			
Sprinkler System Type:	Wet	Specified Area Of Application:	72.00 m ²
Minimum Desired Density:	4.999 Lpm/m ²	Application Average Density:	8.301 Lpm/m ²
Application Average Area Per Sprinkler:	8.00 m ²	Sprinkler Flow:	597.70 Lpm
Average Sprinkler Flow:	66.41 Lpm		
Flow Velocity And Imbalance Summary			
Maximum Flow Velocity (In Pipe 19 - 20)	4.02 m/sec	Maximum Velocity Pressure (In Pipe 19 - 20)	8.07 kPa
Allowable Maximum Nodal Pressure Imbalance:	1.5003 kPa	Actual Maximum Nodal Pressure Imbalance:	0.0061 kPa
Actual Average Nodal Pressure Imbalance:	0.0013 kPa	Actual Maximum Nodal Flow Imbalance:	-0.0087 Lpm
Actual Average Nodal Flow Imbalance:	0.0020 Lpm		
Overall Network Summary			
Number Of Unique Pipe Sections:	25	Number Of Flowing Sprinklers:	9
Pipe System Water Volume:	708.39 L	Sprinkler Flow:	597.70 Lpm
Non-Sprinkler Flow:	0.00 Lpm	Minimum Required Residual Pressure At System Inflow Node:	465.34 kPa
Demand Flow At System Inflow Node:	597.74 Lpm		

Thursday, January 11, 2024, 4:23 PM



Thursday, January 11, 2024, 4:23 PM



Naziv firme:

Napravio:

Telefon:

Datum: 17.1.2024.

Kol.	Opis
1	<p>Hydro EN 50-200/194 S2JS ADL-U1</p>  <p>Poznaj! Slika proizvoda se može razlikovati od stvarnog proizvoda</p> <p>Proizvodni broj: Na zahtev</p> <p>Pressure booster pump sets are designed for automatic sprinkler systems, according to EN 12845, in addition to other relevant industry standards.</p> <p>The pumps sets are designed for fire extinguishing systems with clean water and for single or combined water supplies. It is compact, robust and modular system supplied in pre-assembled macro blocks to make transport, handling and installation easy. Communication is guaranteed through ModBus module.</p> <p>The main pumps have end-suction hydraulics. They are fitted with corrosion-resistant material and replaceable wearing parts, back pull-out design through spacer coupling, fitted with high grade mechanical seals and internally tested at the factory according to QCP protocols.</p> <p>The main pumps are equipped with IEC squirrel cage IE3 electric motors that deliver, in continuous operation, at least the power required at the flow corresponding to the NPSH_r value equal to 16 m.</p> <p>The hydraulic components are designed to minimize the pressure loss and the water speed to meet the requirements at the flow rate values stated on the performance curve.</p> <p>The system contains the following components (unless otherwise specified):</p> <ul style="list-style-type: none">• Two hydraulics coupled with driversTwo microprocessor-based control panelsOne pressure maintenance pump and related independent control panelOne modular discharge manifoldTwo concentric tapered adaptersTwo grooved jointsDirect connection port for room sprinklerTwo non-return valvesTwo isolating valvesTwo drain test valvesTwo pump starting assembly pack (two pressure switches, glycerin-filled pressure gauge, isolating valve, bypass line with non-return valve and drain valve)Two pressure sensing switches (pump running)Pressure vesselA set of Jockey pump fittings (connection for priming, non-return valve, two isolating valves and a pressure switch). <p>For more components, contact Grundfos.</p> <p>The two main pumps are configured in a duty / stand-by configuration.</p> <p>Each pumping unit is mounted on a separate baseplate to reduce stress from one unit to the other while assuring layout flexibility. This layout ensures easy access to the narrow pump room entry and handling in case of extraordinary maintenance needs and keeps the system protected.</p>



Naziv firme:

Napravio:

Telefon:

Datum: 17.1.2024.

Kol.	Opis
1	<p>All the items are wired and fitted at the factory within the same unit skid, except for larger main control panels that are supplied loose with proper signals and cable entry tags.</p> <p>Pump, driver, jockey pump and controllers (unless large size) are anchored on a robust electro-welded baseplate. They are painted RAL 3000 and designed to withstand all static and dynamic stress.</p> <p>The baseplates are designed with holes and anchoring lugs for an easy and safe handling ensuring optimal fastening to the plinth or concrete foundation.</p> <p>For further product information, please tick off "Tender text" under "Print/PDF".</p>









Naziv firme:

Napravio:

Telefon:

Datum: 17.1.2024.

Opis	Vrednost
Opšte informacije:	
Ime proizvoda::	Hydro EN 50-200/194 S2JS ADL-U1
Šifra proizvoda:	Na zahtev
EAN broj::	Na zahtev
Tehnički:	
Stvarno izračunati protok:	598 l/min
Postignuta visina pumpe:	4.887 bar
Electric cooling flow:	33.33 l/min
Nominalni prečnik rotora:	200 mm
Approvals:	CE
Fire standard:	EN 12845
Number of pumps:	3
Backup pumps:	1
Main pump type:	NKF 50-200/194
Number of electrical driven pumps:	2
Jockey pump type:	CM3-8
Number of Jockey pumps:	1
Materijali:	
Kućište pumpe:	Liveno gvožđe
Pump housing:	EN-GJL-250
Rotor:	Bronza
Manifold:	Pocinkovani čelik
Ugradnja:	
Opseg temperature okruženja:	5 .. 40 °C
Relative humidity:	50 %
Maksimalni radni pritisak:	16 bar
Type of inlet connection:	DIN
Type of outlet connection:	DIN
Veličina usisnog priključka:	DN 65
Size of outlet connection:	DN 80
Type of inlet connection for Jockey pump:	Rp
Size of inlet connection for Jockey pump:	1 1/4 inch
Earth connection:	PE
Elevation above sea level:	1000 m
Tečnost:	
Dizana tečnost:	voda
Raspon temperature tečnosti:	0 .. 40 °C
Selected liquid temperature:	20 °C
Gustina:	998.2 kg/m³
Kinematska viskoznost:	1 mm²/s
Elektro podaci:	
Motor standard:	IEC
Driver type:	Električni motor
Mains supply for electrical motor:	3 x 400 V
Potrebna snaga - P2:	15 kW
Frekvencija struje:	50 Hz
Rated current:	27.5 A
Struja pokretanja:	840 %
Motor nominal speed (w/o slip):	2940 rpm
Broj polova:	2
Method of start:	Direct-on-line (DOL)
Klasa zaštite (IEC 34-5):	IP54
Motor standard for Jockey pump:	IEC
Mains supply for jockey motor:	3 x 400 V
Rated power - P2 for Jockey pump:	1.1 kW





Naziv firme:

Napravio:

Telefon:

Datum: 17.1.2024.

Opis	Vrednost
Rated current for Jockey pump:	2.55 A
Number of poles for Jockey pump:	2
Method of start for Jockey pump:	Direct-on-line (DOL)
Ostali:	
Net weight:	799 kg
Gross weight:	918 kg
Country of origin:	IT
Custom tariff no.:	84137059




Naziv firme:

Napravio:

Telefon:

Datum: 17.1.2024.

Na zahtev Hydro EN 50-200/194 S2JS ADL-U1 50 Hz



Napomena! Sve jedinice su u [mm] ukoliko drugačije nije navedeno.
Upozorenje: Ovaj pojednostavljeni dimenzioni crtež ne pokazuje sve detalje.

SPRINKLER INSTALACIJE					
BR.	OPIS POZICIJE	Jedinica	Količina	Jedinična cijena	Ukupna cijena
A ISPORUKA I UGRADNJA OPREME I MATERIJALA					
1	<p>Pumpno postrojenje u skladu sa EN12845: Izrada i isporuka pumpnog postrojenja za transport i povišenje pritiska vode u sistemu za protivpožarnu instalaciju. (1 elektro pumpa radna, 1 elektro pumpa rezervna, 1 džokej pumpa za održavanje pritiska) na zajedničkom postolju povezane sa usisnim potisnim cjevovodom-komplet sa zaustavnim i nepovratnim ventilima i manometrima. U sklopu blok izvedbe ugrađene su pritisne sklopke, i uklopni elektro ormani. Sve je označeno i povezano u sklopu postrojenja i potrebno je da se samo dovede i poveže odgovarajući kabl (el. priključak mora da se uradi stručno i po zahtjevu postrojenja, a u skladu sa propisima). Vrijednosti parametara električnog napajanja naznačiće se na el.šemi najlepnicama-tablicama el.motora. Postrojenje se isporučuje sa Kontra prirubnicama i slijepim prirubnicama, elementima za vezu i dihtovanje Potrebno je da postrojenje zadovolji sljedeće uslove: Protok: Q1 = 1113 l/min; Q2 = 598 l/min Napor: Δp1 = 2.1 bar; Δp2 = 4.65 bar Tip pumpnog postrojenja: Hydro EN 50-200/194 S2JS ADL-U1 Proizvođač: GRUNDFOS ili ekvivalentno U kompletu sa Set za povezivanje pumpi Mjerač protoka EN12845 Ekscentrična redukcija Leptir ventil</p>	kompl.	1	33,609.81	33,609.81
5	<p>Mokri sprinkler ventil sa ovalnim zasunom, presostatom za nadzor stanja klapne, komorom za odloženo dejstvo presostata 2 manometra, ventilom za drenažu i ventilom za testiranje alarmnog zvona Tip: J-1 ANSI-PN 4"+E-T F/F Proizvođač: VIKING ili ekvivalentno DN100 Sertifikat: UL/FM/CE/VdS</p>	kompl.	2	2,272.94	4,545.88
6	<p>Alarmno Zvono Tip: AG-F2 Proizvođač: VIKING ili ekvivalentno Sertifikat: UL/FM</p>	kompl.	2	327.58	655.16
7	<p>Mlaznica stojeća 5 mm staklena ampula 68°C, K=80, 1/2"NPT spoljni navoj, bijela Proizvođač: VIKING ili ekvivalentno Sertifikat: UL/FM/VdS</p>	kom.	65	9.35	608.03
8	<p>Mlaznica viseća 5 mm staklena ampula 68°C, K=80, 1/2"NPT spoljni navoj, bijela Proizvođač: VIKING ili ekvivalentno Sertifikat: UL/FM/VdS</p>	kom.	579	6.76	3,913.98
9	<p>Zaštitna rozetna dvodijelna Tip: EV-1/2"-75/15 BIJELA Proizvođač: VIKING ili ekvivalentno</p>	kom.	579	1.18	685.07

BR.	OPIS POZICIJE	Jedinica	Količina	Jedinična cijena	Ukupna cijena
10	Fleksibilno crijevo S-FLEX VK27SBT1000 DN25/DN15, l=1000 mm Proizvođač: VIKING ili ekvivalentno	kom.	579	20.73	12,002.07
11	Ključ za montažu mlaznica Tip: STANDARD Proizvođač: VIKING ili ekvivalentno Sertifikat: VdS	kom.	2	62.47	124.95
12	Orman za rezervne mlaznice Tip: SHC24 HEAD SPK Kapacitet: 24 mlaznica Proizvođač: VIKING ili ekvivalentno	kom.	1	101.94	101.94
13	Rezervna mlaznica stojeća 5 mm staklena ampula 68°C, K=80, 3/4"NPT spoljni navoj, bijela Proizvođač: VIKING ili ekvivalentno Sertifikat: UL/FM/VdS	kom.	6	9.35	56.13
14	Rezervna mlaznica viseća 5 mm staklena ampula 68°C, K=80, 3/4"NPT spoljni navoj, bijela Proizvođač: VIKING ili ekvivalentno Sertifikat: UL/FM/VdS	kom.	18	6.76	121.68
15	Ovalni zasun DN100 NP16 Tip: NRF 11-0400PN FIREKING Proizvođač: VIKING ili ekvivalentno Sertifikat: UL/VdS	kom.	17	294.98	5,014.64
16	Ovalni zasun DN65 NP16 Tip: NRF 11-0250PN FIREKING Proizvođač: VIKING ili ekvivalentno Sertifikat: UL/VdS	kom.	1	265.09	265.09
17	Hvatač nečistoće DN 100 PN16 Tip: YSF-0400 Proizvođač: VIKING ili ekvivalentno Sertifikat: UL	kom.	1	238.88	238.88
18	Manometri 0-16 bar sa manometarskim ventilom Tip: ER-2MAZ Proizvođač: VIKING ili ekvivalentno Sertifikat: FM	kom.	2	30.11	60.22
19	Nepovratni ventil DN100 NP16 Tip: SCF-0400PN Proizvođač: VIKING ili ekvivalentno Sertifikat: UL/FM	kom.	2	195.66	391.33
20	Set za testiranje indikatora protoka Tip: K30, R3/4"-R1/2" bez fiksne konekcije Proizvođač: VIKING ili ekvivalentno Sertifikat: VdS	kom.	17	117.80	2,002.68
21	Indikator protoka DN100 NP16 Tip: VSR0400CE Proizvođač: VIKING ili ekvivalentno Sertifikat: VdS	kom.	16	242.93	3,886.91
22	Indikator protoka DN65 NP16 Tip: VSR0250CE Proizvođač: VIKING ili ekvivalentno Sertifikat: VdS	kom.	1	242.93	242.93
23	Mikroprekidač koji daje informaciju o položaju zasuna (otvoreni/djelimično otvoreni) Tip: BISU1ZWL Proizvođač: VIKING ili ekvivalentno Sertifikat: VdS	kom.	18	72.15	1,298.65


BR.	OPIS POZICIJE	Jedinica	Količina	Jedinična cijena	Ukupna cijena
24	Nosač za mikroprekidač DN50-DN300 Tip: NF3352SWV-01 Proizvođač: VIKING ili ekvivalentno	kom.	18	6.50	117.01
25	Loptasti ventil DN25 sa priključkom za crijevo za ispiranje cjevovoda	kom.	10	11.02	110.25
26	Automatski ventil za okapavanje DN 15	kom.	1	3.74	3.74
27	Priklučak za vatrogasno vozilo u kompletu sa 2 brze spojnice i 2 brze slijepе spojnice Proizvođač: VIKING ili ekvivalentno Sertifikat: VdS	kompl.	1	341.36	341.36
28	Prirubnica sa grлом PN10/16, DN 100, u kompletu sa dihtungom,vijcima i maticama	kom.	42	5.96	250.23
29	Prirubnica sa grлом PN10/16, DN 65, u kompletu sa dihtungom,vijcima i maticama	kom.	1	4.22	4.22
30	Slijepa prirubnica PN16, DN100	kom.	1	0.00 48.72	48.72
31	Drenažni set Pocinkovane cijevi DN 50 pocinkovane cijevi DN 25,pocinkovani fitting,ljevak kod sprinkler ventila ljevak kod alarmnog zvona sprovedeno do najbližeg slivnika	kompl.	1	180.00	180.00
32	Čelične bešavne crne cijevi Prema MEST EN 10220:2011 Prije montaže neophodno je mehanički i hemijski tretirati cijevi, do uklanjanja svih korozivnih elemenata i oštećenja nastalih oksidacijom.				
	DN100(114,3x3,6)	m kg	440 4356	2.26	9,827.50
	DN65(76,1x3,2)	m kg	76 479.56	2.26	1,081.93
	DN50(60.3x3.65)	m kg	168 856.8	2.26	1,933.01
	DN40(48.3x3.25)	m kg	120 433.2	2.32	1,003.04
	DN32(42.4x3.25)	m kg	168 527.52	2.37	1,252.73
	DN25(33.7x3.25)	m kg	1302 3176.88	2.37	7,544.30
33	FITING (crni)				
	Koljeno 90° DN100	kom.	53	7.21	382.03
	T komad DN100	kom.	25	25.32	633.06
	Koljeno 90° DN65	kom.	3	2.75	8.25
	T komad DN65	kom.	10	12.29	122.86
	Redukcija DN100/DN65	kom.	10	7.20	72.00
	Redukcija DN65/DN50	kom.	21	0.00 3.40	71.32
34	FITING (pocinkovani)				

BR.	OPIS POZICIJE	Jedinica	Količina	Jedinična cijena	Ukupna cijena
	T komad DN50	kom.	74	7.06	522.77
	T komad DN40	kom.	50	4.73	236.64
	T komad DN32	kom.	63	3.71	233.49
	T komad DN25	kom.	201	2.44	489.64
	Koljeno 90° DN50	kom.	20	5.67	113.45
	Koljeno 90° DN40	kom.	3	3.83	11.48
	Koljeno 90° DN32	kom.	15	2.91	43.59
	Koljeno 90° DN25	kom.	402	2.26	909.32
	Redukcija DN50/DN40	kom.	33	3.15	103.93
	Redukcija DN50/DN32	kom.	18	3.15	56.69
	Redukcija DN50/DN25	kom.	64	3.15	201.56
	Redukcija DN40/DN32	kom.	30	2.28	68.38
	Redukcija DN40/DN25	kom.	68	2.28	155.00
	Redukcija DN32/DN25	kom.	128	1.95	249.45
	Redukcija DN25/DN15	kom.	642	1.17	748.44
35	Osnovna boja i razređivač (dva premaza)	lit	100	4.80	480.00
36	Pokrivna boja i razređivač (dva premaza)	lit	100	4.80	480.00
37	Obujmice bez gume-šelne Proizvođač: MEFA ili ekvivalentno DN100 DN65 DN50 DN40 DN32 DN25	kom.	250 40 100 80 100 800	2.64 2.38 1.18 0.90 0.80 0.71	661.20 95.35 118.32 72.38 80.04 570.72
38	Nosači Navojna šipka, L profil, metalni tipi (uračunato u prethodnu stavku) M10, kvaliteta 8.8 Tip: EA II F120 DN100 DN65 DN50 DN40 DN32 DN25	kom.	250 40 100 80 100 800	2.56 2.56 2.56 2.56 2.56 2.56	639.45 102.31 255.78 204.62 255.78 2,046.24
39	Materijal za izradu raznih čeličnih nosača za cjevovod i podstanicu	kg	100	6.48	648.00
105,667.60					

BR.	OPIS POZICIJE	Jedinica	Količina	Jedinična cijena	Ukupna cijena
B	Montaža sa farbanjem cijevi i potrošnim materijalom				52,888.00
C	Snimanje i izrada projekta izvedenog stanja				450.00
D	Ispitivanje i puštanje u rad				350.00
E	Obuka i izrada uputstava za rad				250.00
		UKUPNO BEZ PDV:			159,605.60
		PDV 21%			33,517.18
		UKUPNO SA PDV:			193,122.77

GRAFIČKA DOKUMENTACIJA







Pregled Neto površine - Prizemje		Obrada zida		Obrada podova		Obim (m ²)		Površina (m ²)	
01. Poslovni prostor	Disperzivno boj					1,918,50	21,92		
13. Konferencijska	Disperzivno boj					2,265,50	25,99		
18. Konceratija	Disperzivno boj					1,755,50	15,25		
19. Konceratija	Disperzivno boj					2,353,00	33,92		
21. Konceratija / vježbana	Disperzivno boj					1,620,00	13,69		
02. Informacijski put	Disperzivno boj					Komene ploče	1,314,86	10,12	
03. Viterijenski prostor	Disperzivno boj					Komene ploče	1,294,50	9,70	
15. Hol	Disperzivno boj					Komene ploče	6,935,86	126,99	
04. Hol	Disperzivno boj					Komene ploče	1,769,50	20,87	
05. Prenos oružja	Disperzivno boj					Komene ploče	1,433,50	13,87	
06. Uloc za sjeverne strane	Disperzivno boj					Komene ploče	1,291,50	9,97	
07. Vježbana	Disperzivno boj					Komene ploče	1,303,00	9,42	
10. Konferencijska sala	Disperzivno boj					Baloni plančaste konforata - BI	4,420,07	108,30	
11. Konferencijska sala	Disperzivno boj					Baloni plančaste konforata - BI	4,510,00	10,10	
12. Predstorski salo	Disperzivno boj					Baloni plančaste konforata - BI	1,919,33	22,14	
13. Protokolska sala	Disperzivno boj					Baloni plančaste konforata - BI	2,434,07	34,03	
14. Konceratija	Disperzivno boj					Baloni plančaste konforata - BI	1,703,00	17,59	
15. Konceratija	Disperzivno boj					Baloni plančaste konforata - BI	1,795,50	18,73	
16. Konceratija	Disperzivno boj					Baloni plančaste konforata - BI	1,796,00	19,29	
20. Konceratija	Disperzivno boj					LVT 0039 - BI	1,568,50	14,04	
22. Hodnik	Disperzivno boj					Komene ploče	2,237,00	17,43	
23. Toalet - muški	Disperzivno boj					Keramicke pločice	1,747,00	9,41	
24. Toalet - ženski	Disperzivno boj					Keramicke pločice	1,700,00	10,10	
25. Toalet - lice sa invaliditetom	Disperzivno boj					Keramicke pločice	1,779,00	3,54	
26. Stepničke	Disperzivno boj					Komene ploče	1,692,50	17,89	

Legenda označka

- 5. Označka sopstvene brojne ploče
- 6. Označka unutrašnje stolice (S - krilo, V - visina, P - predoljni ugao)
- 7. Označka kota konstrukcije
- 8. Označka kota završne obrade
- 9. Označka kota pester površina
- 10. Označka glevnog ulaza
- 11. Označka podova / noge
- 12. Označka kota peščanih površina

Legenda srađiva presečenih materijala

- Armišten beton
- Beton
- Gitter blok
- Staklo
- Kamen
- Bovit-zavrsni sloj
- Keramicke pločice
- Aluminij
- Materij (prodruž)
- Gips-karton
- Gips-skladiste
- Gips-karton
- Gips-karton
- Temperozolatski asfalt
- Asfalt
- Cementni esterh
- Ljubazni sloj
- Ferobeton

Legenda srađiva materijala u izgledu

- Trotor
- Keramicke pločice
- Granit keramika
- Beton plote
- Kamen ploče
- Profilišeni im
- Ferobeton
- Asfalt
- Trotor
- Trava
- Sjunk

LEGENDA:

- CELJICNE BESAVNE CJEVCI**: JUS C.B.221 (DIN2448)
- CELJICNE BESAVNE CJEVCI**: JUS.C.B.225 (DIN 2440)
- MAGISTRALNI CJEVOVOD MOKROG SPRINKLER**
- VENTIL**
- GRANE SA SPRINKLER MLAZNICAMA**
- VISIČA SPRINKLER MLAZNICA** (k=80, t=68°C, 1/2", 5 mm AMPULA)

Pregled bruto i neto površina

Bruto površina objekta (uzeti u obrudu BRGP)	5,136,50 m ²
Bruto površina objekta (ne uzeti u obrudu BRGP)	1,620,84 m ²
Ukupno bruto površina objekta	6,757,34 m ²
Ukupno neto površina objekta	5,773,12 m ²
Ukupno površina podzemnih etaza	5,136,50 m ²
Ukupno površina nadzemnih etaza	4,345,00 m ²
Ukupno neto površina podzemnih etaza	1,620,84 m ²
Ukupno neto površina nadzemnih etaza	1,428,12 m ²

Napomene

- Sve kote su date u centimetrima (dužinski) i metrima (visinske), a površine u m².
- Kod zidova nije količina njihove zadržavajuće moći AB počeće do donje ljevičarske konstrukcije (zadržavne obloge).
- Sve mjere za zrcalo vrata, proračun proverjen na licu mjesto.
- Proračun je vrata i vrata za pogon u skladu s DIN 18096.
- Parapet prizore i vrata je mjerjen od konstrukcije / AB počeće.
- Postavljanje keramike u kupatilima se vrši sa visinom h=30 cm od cementne kobilice.
- Postavljanje keramike u kupatilima se vrši sa visinom h=30 cm od cementne kobilice.

Legenda označka

- 5. Označka sopstvene brojne ploče
- 6. Označka unutrašnje stolice (S - krilo, V - visina, P - predoljni ugao)
- 7. Označka kota konstrukcije
- 8. Označka kota završne obrade
- 9. Označka kota pester površina
- 10. Označka glevnog ulaza
- 11. Označka podova / noge
- 12. Označka kota peščanih površina

Legenda srađiva presečenih materijala

- Armišten beton
- Beton
- Gitter blok
- Staklo
- Kamen
- Bovit-zavrsni sloj
- Keramicke pločice
- Aluminij
- Materij (prodruž)
- Gips-karton
- Gips-skladiste
- Gips-karton
- Gips-karton
- Temperozolatski asfalt
- Asfalt
- Cementni esterh
- Ljubazni sloj
- Ferobeton

Legenda srađiva materijala u izgledu

- Trotor
- Keramicke pločice
- Granit keramika
- Beton plote
- Kamen ploče
- Profilišeni im
- Ferobeton
- Asfalt
- Trotor
- Trava
- Sjunk

LEGENDA:

- CELJICNE BESAVNE CJEVCI**: JUS C.B.221 (DIN2448)
- CELJICNE BESAVNE CJEVCI**: JUS.C.B.225 (DIN 2440)
- MAGISTRALNI CJEVOVOD MOKROG SPRINKLER**
- VENTIL**
- GRANE SA SPRINKLER MLAZNICAMA**
- VISIČA SPRINKLER MLAZNICA** (k=80, t=68°C, 1/2", 5 mm AMPULA)

Pregled bruto i neto površina

Bruto površina objekta (uzeti u obrudu BRGP)	5,13
--	------







Obrada plafona	Obim (m')	Površina (m ²)
Disperzivna boja	15,400.36	165.63
Disperzivna boja	2,265.51	29.67
Disperzivna boja	2,595.14	37.61
Disperzivna boja	1,699.64	14.29
Disperzivna boja	1,738.64	18.39
Disperzivna boja	1,738.64	18.39
ski Disperzivna boja	2,746.45	33.27
ski Disperzivna boja	1,960.59	21.28
Disperzivna boja	2,147.73	22.85
Disperzivna boja	2,119.70	23.79
Disperzivna boja	2,074.65	22.83
Disperzivna boja	2,015.33	20.29
Disperzivna boja	1,813.01	19.65
Disperzivna boja	2,494.45	28.95
Disperzivna boja	1,651.86	16.77
Disperzivna boja	2,167.22	21.93
Disperzivna boja	2,643.00	40.80
ce Disperzivna boja	1,671.00	9.41
ce Disperzivna boja	1,701.00	10.10
ce Disperzivna boja	779.00	3.54
ka Disperzivna boja	1,294.50	9.69
Disperzivna boja	1,866.00	18.97
ce Disperzivna boja	1,170.50	6.79
ce Disperzivna boja	1,392.00	9.35
		624.24 m ²

ka	Disperzivna boja	1,068.50	7.06	
ka	Disperzivna boja	930.00	5.08	
ka	Disperzivna boja	936.50	5.13	
			17.27 m ²	
		641.51 m ²		

Legenda oznaka

	Oznaka sopljašnje bravarije (Š – širina, V – visina, P – parapet)	Zidovi Pod
	Oznaka unutrašnje stolarije (Š – širina, V – visina, P – parapet)	Plafon Ograda
	Apsolutna kota konstrukcije	Rukohvat
	Relativna kota konstrukcije	PUT Pod uređenja terena
	Relativna kota završne obrade	
	Relativna kota plafona	Oznaka pristupa parceli
	Relativna kota zelenih površina	
		Oznaka glavnog ulaza

Legenda šrafura presječenih materijala

	Giter blok		Staklo		Kamen		Bavalit-završni sloj
	Malter (produžni)		Gips-kartonska ploča		Gips-kartonska (vlagoboljuporna)		Gips-kartonska (vatrogosporna)
	Asfalt		Cementni estrih		Libazni sloj		Ferobeton
	Kamene ploče		Šljunak		Šljunak iz iskopa		Šljunak (nabijeni)
	Humus						

Legenda šrafura materijala u izgledu

	Granitna keramika		Behaton ploče		Kamene ploče		Profilisani lim
	Trotoar		Trava		Sljunak		

ČELIČNE BEŠAVNE CIJEVI JUSC.B5.225 (DIN 2440)

DN50(60,3x3,65 mm)

DN40(48,3x3,25 mm)

DN32(42,4x3,25 mm)

DN25(33,7x3,25 mm)


OD MOKROG SPRINKLER


MLAZNICAMA AZNICA AMPULA)


Pregled bruto i neto površina
Napomene
(dužinske) i metrima (visinske), a površine u m².
avršna obrada.
od gornje ivice AB ploče do donje ivice plafonske konstrukcije (završne obrada provjeriti na licu mjesta).
oduzimanjem slojeva zidova.
od konstrukcije / AB ploče.
anje hidroizolacije na zidovima na visini h=30 cm od cementne košuljice.
se vrši do plafona.

OBJECTS PROJEKTANT:	INVESTITOR:
JSC "NEGRO" d.o.o. projektovanje, inženjeriranje 81000 Podgorica, Montenegro	Uprava za katastar i državnu imovinu Podgorica, Crna Gora
alnog administrativnog rgana državne uprave	Lokacija: UP5 koju čine k.p. 2212, 2215/1, 2216 KO Podgorica II, u zahvatu DUP-a "Nova Varoš 2"
ko Bešović, spec.sci.	Vrsta tehničke dokumentacije: GLAVNI PROJEKAT
Ivorac dipl.maš.ing	Dio tehničke dokumentacije: MAŠINSTVO - SPRINKLER
gjelevski dipl.maš.ing.	Prilog: Osnova 3 sprata - Sprinkler sistem
	Datum revizije i M.P.
23-Jan-24	Br. priloga: D Br. strane: 6









PROJEKTANT:	UPRava za katastar i državnu imovinu Podgorica, Crna Gora	
GFM green projects montenegro d.o.o.	Društvo za razvoj i projekti u interesu državnih i lokalnih organa	Projektni partner
Objekat:	Adaptacija multifunkcionalnog administrativnog objekta za potrebe organa državne uprave	Lokacija: UP5 koji čine k.p. 2212, 2215/1, 2216 KO Podgorica II, u zahvatu DUP-a "Nova Varoš"
Glavni inženjer:	arh. Marko Bešović, spec.sci.	Vrsta tehničke dokumentacije: GLAVNI PROJEKAT Oznaka projekta: GP ID 14/23
Odgovorni inženjer:	Goran Korač dipl. maš. ing.	Dio tehničke dokumentacije: MASINSTVO - SPRINKLER Razmjera:
Saradnik:	Marjan Gjorgjević dipl. maš. ing.	Prilog: Br. priлог: Br. strane: D 10
Datum izrade i M.P.		Datum revizije i M.P.

